

BDSR REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	DURATION	FAULT REASON
5/21/2026 10:48:22 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-AMETHI	EDD-BHETUA		Link Feeder	33/11 KV HAL	Scheduled Rostering	731804024	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:48:22 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-AMETHI	EDD-BHETUA		Munshiganj	33/11 KV HAL	Scheduled Rostering	731804024	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:48:22 PM	MWNL	AYODHYA	AYODHYA	EDC-RUDAUHU	EDD-RUDAUHU	EDD-RUDAUHU	all feeder substation sidpur	KASARI	33/11 KV SAIDPUR	Scheduled Rostering	735595865	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:48:34 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUHU	EDD-RUDAUHU	all feeder substation sidpur	Nagar Panchayat	33/11 KV SAIDPUR	Scheduled Rostering	735595865	05/21/26 10:45:00 PM	2 H 0 M	Rostering
5/21/2026 10:46:04 PM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-LAMBHUA	EDD-CHANDAA		Kindpur	KINDUPUR_324843	Scheduled Rostering	811596164	05/21/26 10:20:00 PM	2 H 0 M	Rostering
5/21/2026 10:46:04 PM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-LAMBHUA	EDD-CHANDAA		Madhyaha	KINDUPUR_324843	Scheduled Rostering	811596164	05/21/26 10:20:00 PM	2 H 0 M	Rostering
5/21/2026 10:45:34 PM	MWNL	RAE BARELI	RAEBARELI	EDC-1 RAE BARELI	EDD-TRIPULUA	EDD-TRIPULUA	11 kv vahli dareba lodhwanmu munshiganj feeder	Munshiganj	33/11 TRIPULUA	Emergency Rostering	800492180	05/21/26 10:44:00 PM	2 H 0 M	Overloading
5/21/2026 10:45:34 PM	MWNL	RAE BARELI	RAEBARELI	EDC-1 RAE BARELI	EDD-TRIPULUA	EDD-TRIPULUA	11 kv vahli dareba lodhwanmu munshiganj feeder	Lodhwanmu	33/11 TRIPULUA	Emergency Rostering	800492180	05/21/26 10:44:00 PM	2 H 0 M	Overloading
5/21/2026 10:45:34 PM	MWNL	RAE BARELI	RAEBARELI	EDC-1 RAE BARELI	EDD-TRIPULUA	EDD-TRIPULUA	11 kv vahli dareba lodhwanmu munshiganj feeder	Raahi	33/11 TRIPULUA	Emergency Rostering	800492180	05/21/26 10:44:00 PM	2 H 0 M	Overloading
5/21/2026 10:45:34 PM	MWNL	RAE BARELI	RAEBARELI	EDC-1 RAE BARELI	EDD-TRIPULUA	EDD-TRIPULUA	11 kv vahli dareba lodhwanmu munshiganj feeder	Darebaha	33/11 TRIPULUA	Emergency Rostering	800492180	05/21/26 10:44:00 PM	2 H 0 M	Overloading
5/21/2026 10:45:30 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-TANDA	EDD-TANDA	whole substation	Chalgapur	ALIGANI	Emergency Rostering	9005973541	05/21/26 10:00:00 PM	1 H 0 M	Transmission Rostering
5/21/2026 10:45:30 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-TANDA	EDD-TANDA	whole substation	Sub-Station	ALIGANI	Emergency Rostering	9005973541	05/21/26 10:00:00 PM	1 H 0 M	Transmission Rostering
5/21/2026 10:45:30 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-TANDA	EDD-TANDA	whole substation	Alijan	ALIGANI	Emergency Rostering	9005973541	05/21/26 10:00:00 PM	1 H 0 M	Transmission Rostering
5/21/2026 10:45:30 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-TANDA	EDD-TANDA	whole substation	CHIC	ALIGANI	Emergency Rostering	9005973541	05/21/26 10:00:00 PM	1 H 0 M	Transmission Rostering
5/21/2026 10:45:30 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-GAURIGANI	EDD-GAURIGANI	whole substation	Adeeh Janta	ALIGANI	Emergency Rostering	9005973541	05/21/26 10:00:00 PM	1 H 0 M	Transmission Rostering
5/21/2026 10:44:19 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-GAURIGANI	EDD-GAURIGANI		गौरीजी	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:44:19 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-GAURIGANI	EDD-GAURIGANI		बाराही	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:44:19 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-GAURIGANI	EDD-GAURIGANI		पौरी	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 10:40:00 PM	2 H 0 M	Rostering
5/21/2026 10:43:37 PM	MWNL	LUCKNOW	AMMAUS	LUCKNOW RURAL	EDD-MOHANLAGANJ	EDD-GOSAIGANJ		GOSAIGANJ	GOSAIGANJ	Breakdown Shutdown	8004921268	05/21/26 10:37:00 PM	3 H 11 M	DT Damaged/DT Fuse Burn/Fire on DT
5/21/2026 10:42:26 PM	MWNL	Lakhipur KHERI	SITAPUR	EDD-LAKHIMPUR	EDD-2 Lakhimpur (MITAUL)	EDD-MAHEWA GANJ	पूव नम निजाम पूव दिनेशमजम	Laksar	GOSAIGANJ	Emergency Rostering	9795513115	05/21/26 10:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:42:26 PM	MWNL	Lakhipur KHERI	SITAPUR	EDD-LAKHIMPUR	EDD-2 Lakhimpur (MITAUL)	EDD-MAHEWA GANJ		Kaimaha	Kaimaha	Emergency Rostering	9795513115	05/21/26 10:30:00 PM	3 H 0 M	Transmission Rostering
5/21/2026 10:42:26 PM	MWNL	Lakhipur KHERI	SITAPUR	EDD-LAKHIMPUR	EDD-2 Lakhimpur (MITAUL)	EDD-MAHEWA GANJ		Bhadura	Kaimaha	Emergency Rostering	9795513115	05/21/26 10:30:00 PM	3 H 0 M	Transmission Rostering
5/21/2026 10:37:26 PM	MWNL	SITAPUR	SITAPUR	EDD-SITAPUR	EDD-SIDHAULI	EDD-KHAIARBAD	रौंरिण रोन के बरण कीर सरनवीर कर डेर के अउरि रीरि डेर	Sub Station	Kasarla	Scheduled Rostering	783051686	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 10:37:26 PM	MWNL	SITAPUR	SITAPUR	EDD-SITAPUR	EDD-SIDHAULI	EDD-KHAIARBAD	रौंरिण रोन के बरण कीर सरनवीर कर डेर के अउरि रीरि डेर	Tagasa Khajuria	Kasarla	Scheduled Rostering	783051686	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 10:37:26 PM	MWNL	SITAPUR	SITAPUR	EDD-SITAPUR	EDD-SIDHAULI	EDD-KHAIARBAD	रौंरिण रोन के बरण कीर सरनवीर कर डेर के अउरि रीरि डेर	Para Sarai	Kasarla	Scheduled Rostering	783051686	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 10:37:26 PM	MWNL	SITAPUR	SITAPUR	EDD-SITAPUR	EDD-SIDHAULI	EDD-KHAIARBAD	रौंरिण रोन के बरण कीर सरनवीर कर डेर के अउरि रीरि डेर	Kasarla Tharabad	Kasarla	Scheduled Rostering	783051686	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 10:31:30 PM	MWNL	BAREILLY	BAREILLY-1	EDC-ADNLA	EDD-ADNLA	EDD-ADNLA	churaha	ANTUA (AG)	33/11 BV BISHRAGANJ (Antua)	Breakdown Shutdown	945881612	05/21/26 10:11:00 PM	6 H 0 M	11KV Line Fault
5/21/2026 10:31:30 PM	MWNL	BAREILLY	BAREILLY-1	EDC-ADNLA	EDD-ADNLA	EDD-ADNLA	churaha	PREMABPUR (AG)	33/11 BV BISHRAGANJ (Antua)	Breakdown Shutdown	945881612	05/21/26 10:11:00 PM	6 H 0 M	11KV Line Fault
5/21/2026 10:33:02 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISALU	EDD-3 BISALU		SETA KHEDA	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:33:02 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISALU	EDD-3 BISALU		Parvej Nagar	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:33:02 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISALU	EDD-3 BISALU		HARDASPUR	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:33:02 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISALU	EDD-3 BISALU		Jarara	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:33:02 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISALU	EDD-3 BISALU		PARVEZNAGAR (Dabthuri)	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		Mailepur	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		Salemgar	PARVEZNAGAR (Dabthuri)	Scheduled Rostering	7055380110	05/21/26 10:32:00 PM	2 H 0 M	Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		MAGRIR	33/11 KV S/S BEEGHAPUR	Emergency Rostering	9453005036	05/21/26 10:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		ACHALGANJ	33/11 KV S/S BEEGHAPUR	Emergency Rostering	9453005036	05/21/26 10:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		OSIA	33/11 KV S/S BEEGHAPUR	Emergency Rostering	9453005036	05/21/26 10:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		Bara	33/11 KV S/S BEEGHAPUR	Emergency Rostering	9453005036	05/21/26 10:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:31:14 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-3 PURWA		BEHTA	33/11 KV S/S BEEGHAPUR	Emergency Rostering	9453005036	05/21/26 10:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 10:28:12 PM	MWNL	LUCKNOW	GOMTI NAGAR	INDIRA NAGAR	EDD-MUNSHIPULUA	INDIRA NAGAR SECT-14 OLD	Raghura nagar me abc me aag lagne ke karan band kya gya feeder	PATEL NAGAR	MANILA POLITECHNIC	Breakdown Shutdown	8004005661	05/21/26 10:27:00 PM	0 H 30 M	17VABC Line Fault
5/21/2026 10:28:12 PM	MWNL	LUCKNOW	GOMTI NAGAR	INDIRA NAGAR	EDD-MUNSHIPULUA	INDIRA NAGAR SECT-14 OLD	हरे रबी रुरार नर के कर डेर	PATEL NAGAR	MANILA POLITECHNIC	Planned Shutdown	8004005661	05/22/26 9:00:00 PM	2 H 0 M	DT Maintenance
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		HARDASPUR	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 2:31:00 PM	1 H 8 M	33KV Line Fault
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		MAWAI	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 2:33:00 PM	1 H 8 M	33KV Line Fault
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		KARDHAHA	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 2:33:00 PM	1 H 8 M	33KV Line Fault
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		LADWA	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 2:33:00 PM	1 H 8 M	33KV Line Fault
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		SUB STATION	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 2:33:00 PM	1 H 8 M	33KV Line Fault
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		HARDI	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		MAWAI	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		KARDHAHA	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		LADWA	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		HILAUU	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:25:59 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDD-MAURAWN		SUB STATION	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 10:00:00 PM	2 H 0 M	Rostering
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Baruhasulpur (AG)	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Barua Hing Gramin	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Padai Znd	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Padai (AG)	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Bhagnapur lind	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Kuan Danda	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:27:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR		Badu	33/11 KV BHUTA	Breakdown Shutdown	9453005137	05/21/26 10:21:00 PM	1 H 30 M	33KV Line Fault
5/21/2026 10:26:06 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-2 BAREILLY	EDD-I FARIDPUR								

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON	
5/21/2026 10:09:21 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-PATRANGA		NEVRA	33/11 KV P/ MAWAJ	Emergency Rostering	9453262037	05/21/26 10:08:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 10:09:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDDS-HASANGANJ		NEWTANI	33/11 KV Hasanganj Tehsil Unnao	Emergency Rostering	9415099240	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:09:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDDS-HASANGANJ		SUBSTATION	33/11 KV Hasanganj Tehsil Unnao	Emergency Rostering	9415099240	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:09:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDDS-HASANGANJ		11 KV HASANGANJ TEHSIL	33/11 KV Hasanganj Tehsil Unnao	Emergency Rostering	9415099240	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:09:07 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-HASANGANJ		11 KV DHUARA	33/11 KV Hasanganj Tehsil Unnao	Emergency Rostering	9415099240	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:53 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-DEVIANGAN	village	SIDOHAI	SIDOHAI	Emergency Rostering	8004402005	05/21/26 10:05:00 PM	1 H 2 M	Transmission Rostering	
5/21/2026 10:06:53 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-DEVIANGAN	village	SIDOHAI	SIDOHAI	Emergency Rostering	8004402005	05/21/26 10:05:00 PM	1 H 2 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI	town	Substation	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 11:30:00 AM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI		Sahagahr	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 10:05:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI		Islam Nagar	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 10:05:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI		Imfi Chauraha	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 10:05:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI		Kotwali	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 10:05:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:06:28 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHERI	EDDS-1 BAHERI		Ram Lila Nuri Nagar	33/11 KV BAHERI TOWN	Emergency Rostering	8004918693	05/21/26 10:05:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:04:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BIKHAPUR		TARABAGANJ	33/11 KV BIKAPUR TASEEL	Emergency Rostering	9415901479	05/21/26 10:03:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:04:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BIKHAPUR		CHANDPUR	33/11 KV BIKAPUR TASEEL	Emergency Rostering	9415901479	05/21/26 10:03:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:04:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BIKHAPUR		BIKAPUR TASEEL	33/11 KV BIKAPUR TASEEL	Emergency Rostering	9415901479	05/21/26 10:03:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:03:32 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-SOHAVAL		Suttaganj	SOHAVAL TEHSIL	Emergency Rostering	8004915074	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:03:22 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-SOHAVAL		Tahseel	SOHAVAL TEHSIL	Emergency Rostering	8004915074	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Tehseel	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Bheolar	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Bherodham	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Nayaganj	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Kothi	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:02:27 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDDS-RUDAUJI		Amrauli Tehseel	Rudauli Tehseel	Emergency Rostering	8004915076	05/21/26 9:55:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:01:21 PM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDDS-KHRO	all	Ainpur	33/11 KV KALLUWA KHEDA	Scheduled Rostering	9415099357	05/21/26 8:35:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:21 PM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDDS-KHRO	all	Ranapur	33/11 KV KALLUWA KHEDA	Scheduled Rostering	9415099357	05/21/26 8:35:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:21 PM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDDS-KHRO	all	Atrahar	33/11 KV KALLUWA KHEDA	Scheduled Rostering	9415099357	05/21/26 8:35:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:21 PM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDDS-KHRO	all	Incoming	33/11 KV KALLUWA KHEDA	Scheduled Rostering	9415099357	05/21/26 8:35:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-I GOLA		MAMI	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 8:45:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		AAJAN	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 8:45:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-III GOLA		MAMI	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 8:45:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-III GOLA		Hari Nagar	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 8:45:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-III GOLA		HYDERABAD	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 11:25:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-III GOLA		MAMI	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 11:25:00 PM	2 H 0 M	Rostering	
5/21/2026 10:01:11 PM	MVNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-III GOLA		MAMI	33/11KV HYDERABAD	Scheduled Rostering	7390870394	05/21/26 11:25:00 PM	2 H 0 M	Rostering	
5/21/2026 10:00:00 PM	MVNL	HARDOI	RAEBARELI	EDC-HARDOI	EDD-SHAHABAD	EDDS-SHAHABAD		SUBSTATION	33/11 KV Shahabad Tehsil	Emergency Rostering	8005490437	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 10:00:00 PM	MVNL	HARDOI	RAEBARELI	EDC-HARDOI	EDD-SHAHABAD	EDDS-SHAHABAD		SITAPUR	33/11 KV Shahabad Tehsil	Emergency Rostering	8005490437	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:57:20 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		BICHITHA (MANGAT KHERA)	33/11 KV S/5 Purwa (old)	Emergency Rostering	9453005038	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:57:20 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		CHAMYANI	33/11 KV S/5 Purwa (old)	Emergency Rostering	9453005038	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:57:20 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		BEHTACOLD STORAGE	33/11 KV S/5 Purwa (old)	Emergency Rostering	9453005038	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:57:20 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		BEHTA	33/11 KV S/5 Purwa (old)	Emergency Rostering	9453005038	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:56:53 PM	MVNL	LUCKNOW RURAL	LUCKNOW RURAL	EDC-AMETHI LESA	EDD-MOHANLALGANJ	EDDS-AMETHI LESA	Kalu bheran kheda	LUCKNOW RURAL	33/11 KV AMETHI LESA	Emergency Rostering	9450029751	05/21/26 9:00:00 PM	2 H 30 M	Transmission Rostering	
5/21/2026 9:56:53 PM	MVNL	LUCKNOW RURAL	AMAUUS	EDC-AMETHI LESA	EDD-MOHANLALGANJ	EDDS-AMETHI LESA	सौरभ फीडर के राजमदारा सोहरुटी में रूरे 250kva f की पोलिटी में आग लगने के कारण	KALUBIRAN KHERA	33/11 KV PURANPUR	Breakdown Shutdown	9450029751	05/21/26 10:35:00 PM	2 H 30 M	LT/ABC Line Fault	
5/21/2026 9:56:53 PM	MVNL	LUCKNOW RURAL	AMAUUS	EDC-AMETHI LESA	EDD-MOHANLALGANJ	EDDS-AMETHI LESA	सौरभ फीडर के राजमदारा सोहरुटी में रूरे 250kva f की पोलिटी में आग लगने के कारण	SEWAI	33/11 KV PURANPUR	Breakdown Shutdown	9450029751	05/21/26 10:35:00 PM	2 H 30 M	LT/ABC Line Fault	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		SHUKU BAZAR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 1:53:00 PM	1 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		HUSAINPUR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 1:53:00 PM	1 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		SUKUL BAZAR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 1:53:00 PM	1 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		Husainpur	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 1:53:00 PM	1 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		SHUKU BAZAR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 9:15:00 PM	2 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		HUSAINPUR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 9:15:00 PM	2 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		SUKUL BAZAR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 9:15:00 PM	2 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-JAGDISHPUR	EDDS-II JAGDISHPUR		SHUKU BAZAR	Shukul Bazar	Scheduled Rostering	948946080	05/21/26 9:15:00 PM	2 H 0 M	Rostering	
5/21/2026 9:56:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		SUB STATION FEEDER	Purwa Tahseel	Emergency Rostering	9415901575	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:56:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		Tahseel	Purwa Tahseel	Emergency Rostering	9415901575	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:56:07 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-III PURWA		Outaganj	Purwa Tahseel	Emergency Rostering	9415901575	05/21/26 9:50:00 PM	1 H 0 M	Transmission Rostering	
5/21/2026 9:52:51 PM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-BISWA	EDDS-BISWAN		GOVERDHAM PUR	33/11 BISWAN RURAL	Breakdown Shutdown	9453005065	05/21/26 8:50:00 PM	2 H 0 M	33KV Line Fault	
5/21/2026 9:52:51 PM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-BISWA	EDDS-BISWAN		सौरभिन नमने के कारण फीडर सम्भरिजत अचुनि बरिजिन है	JAHANGIRA BAD (B)	33/11 BISWAN RURAL	Breakdown Shutdown	9453005065	05/21/26 8:50:00 PM	2 H 0 M	33KV Line Fault
5/21/2026 9:52:51 PM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-BISWA	EDDS-BISWAN		सौरभिन नमने के कारण फीडर सम्भरिजत अचुनि बरिजिन है	KOTHRA	33/11 BISWAN RURAL	Breakdown Shutdown	9453005065	05/21/26 8:50:00 PM	2 H 0 M	33KV Line Fault
5/21/2026 9:52:51 PM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-BISWA	EDDS-BISWAN		सौरभिन नमने के कारण फीडर सम्भरिजत अचुनि बरिजिन है	GOVERDHAM PUR	33/11 BISWAN RURAL	Breakdown Shutdown	9453005065	05/21/26 8:50:00 PM	2 H 0 M	33KV Line Fault
5/21/2026 9:47:01 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDDS-HASANGANJ		SANDANA	33/11 KV Hasanganj Substation	Emergency Rostering	9453006440	05/21/26 8:30:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 9:47:01 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDDS-HASANGANJ		11 KV NAI SARAI	33/11 KV Hasanganj Substation	Emergency Rostering	9453006440	05/21/26 8:30:00 PM			

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 9:37:05 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Pashaur	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:37:05 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Basulpur	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:37:05 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Patihaur-2	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:37:05 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Basulpur-2	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:37:05 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Jamunabad	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:36:17 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Amritapur	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:36:17 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Madrhiwaran	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	9369055562	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:36:17 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Bhngaur	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	9369055562	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:36:17 PM	MVNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Shikpur	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	9369055562	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		SubStation	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	9369055562	05/21/26 7:15:00 PM	2 H 30 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Deviya	33/11 KV S/5 HARH HAR PUR	Scheduled Rostering	7991632792	05/21/26 8:05:00 PM	2 H 0 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Haar Har Pur	33/11 KV S/5 HARH HAR PUR	Scheduled Rostering	7991632792	05/21/26 8:05:00 PM	2 H 0 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Patyala	33/11 KV S/5 HARH HAR PUR	Scheduled Rostering	7991632792	05/21/26 8:05:00 PM	2 H 0 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Gurudwara	33/11 KV S/5 HARH HAR PUR	Scheduled Rostering	7991632792	05/21/26 8:05:00 PM	2 H 0 M	Rostering
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Deviya	33 kv HARIHARPUR line BD	Breakdown Shutdown	7991632792	05/22/26 7:50:00 AM	1 H 0 M	33KV Line Fault
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Haar Har Pur	33 kv HARIHARPUR line BD	Breakdown Shutdown	7991632792	05/22/26 7:50:00 AM	1 H 0 M	33KV Line Fault
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Patyala	33 kv HARIHARPUR line BD	Breakdown Shutdown	7991632792	05/22/26 7:50:00 AM	1 H 0 M	33KV Line Fault
5/21/2026 9:31:20 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II GOLA		Gurudwara	33/11 KV S/5 HARH HAR PUR	Breakdown Shutdown	7991632792	05/22/26 7:50:00 AM	1 H 0 M	33KV Line Fault
5/21/2026 9:25:14 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-2 SULTANPUR	EDDS-I KURWAR		Kurdham	33/11 KV S/5 HARH HAR PUR	Breakdown Shutdown	7991632792	05/22/26 7:50:00 AM	1 H 0 M	33KV Line Fault
5/21/2026 9:23:31 PM	MVNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-2 BADAUN	EDDS-I KAKRALA		TOWN	33/11 KV MIYAU	Breakdown Shutdown	7995568091	05/21/26 9:25:00 PM	11 H 30 M	11KV Line Fault
5/21/2026 9:23:31 PM	MVNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-2 BADAUN	EDDS-I KAKRALA		SAADI	33/11 KV MIYAU	Breakdown Shutdown	7995568091	05/21/26 9:25:00 PM	11 H 30 M	11KV Line Fault
5/21/2026 9:23:31 PM	MVNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-2 BADAUN	EDDS-I KAKRALA		GAUTARA	33/11 KV MIYAU	Planned Shutdown	7995568091	05/21/26 4:20:00 PM	16 H 20 M	OT Maintenance
5/21/2026 9:21:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJU	EDDS-SOHAHAL		KINJHUPUR	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 7:30:00 PM	2 H 0 M	Rostering
5/21/2026 9:21:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJU	EDDS-SOHAHAL		KUNDURKHA KHURD	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 7:30:00 PM	2 H 0 M	Rostering
5/21/2026 9:21:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJU	EDDS-SOHAHAL		DAVODI	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 7:30:00 PM	2 H 0 M	Rostering
5/21/2026 9:21:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJU	EDDS-SOHAHAL		KINJHUPUR	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 9:21:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJU	EDDS-SOHAHAL		KUNDURKHA KHURD	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 9:19:59 PM	MVNL	LYONNAGAR	CONOT NAGAR	EDC-AYODHYA	EDD-SOHAHAL	CONOT NAGAR		CONOT NAGAR	33/11 KV DAVODI	Scheduled Rostering	9519077120	05/21/26 10:15:00 PM	2 H 0 M	Rostering
5/21/2026 9:18:23 PM	MVNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-BALRAMPUR	EDDS-BALRAMPUR		LIFT Canal	EDD-CHINWAT	Emergency Rostering	9670134090	05/21/26 8:05:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Baretha	132/133/11 KV BALRAMPUR	Emergency Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Jaisinghpur(R)	33/11 KV S/5 BAWAN	Scheduled Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Katola	33/11 KV S/5 BAWAN	Scheduled Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Gosainpur	33/11 KV S/5 BAWAN	Scheduled Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Kurebhar(R)	33/11 KV S/5 BAWAN	Scheduled Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:18:02 PM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-JAISINGHPUR	EDDS-I KUREBHAR		Baretha	33/11 KV S/5 BAWAN	Scheduled Rostering	9511997167	05/21/26 9:00:00 PM	1 H 5 M	Rostering
5/21/2026 9:17:33 PM	MVNL	RAE BARELI	RAEBARELI	EDC-I RAEBARELI	EDD-TRIPULA	EDDS-TRIPULA		udhawa	33/11 KV S/5 Sidhaua	Emergency Rostering	9453005005	05/21/26 10:48:00 PM	2 H 0 M	Rostering
5/21/2026 9:17:33 PM	MVNL	RAE BARELI	RAEBARELI	EDC-I RAEBARELI	EDD-TRIPULA	EDDS-TRIPULA		Rashtaha	33/11 KV S/5 Sidhaua	Emergency Rostering	9453005005	05/21/26 10:48:00 PM	2 H 0 M	Rostering
5/21/2026 9:17:33 PM	MVNL	RAE BARELI	RAEBARELI	EDC-I RAEBARELI	EDD-TRIPULA	EDDS-TRIPULA		Chandpur	33/11 KV S/5 Sidhaua	Emergency Rostering	9453005005	05/21/26 10:48:00 PM	2 H 0 M	Rostering
5/21/2026 9:17:33 PM	MVNL	RAE BARELI	RAEBARELI	EDC-I RAEBARELI	EDD-TRIPULA	EDDS-TRIPULA		Amawan	33/11 KV S/5 Sidhaua	Emergency Rostering	9453005005	05/21/26 10:48:00 PM	2 H 0 M	Rostering
5/21/2026 9:15:05 PM	MVNL	SHAJAHANPUR	BARILLY-2	EDC-SHAJAHANPUR	EDD-1 SHAJAHANPUR	EDDS-I JAMAUJ		kahelya	33/11 KV BADSHAHNAGAR	Breakdown Shutdown	9415901740	05/21/26 6:38:00 PM	4 H 0 M	11KV Line Fault
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Stadium	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/21/26 8:05:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Lotar	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/21/26 8:05:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Lonar	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/21/26 8:05:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Saityapur	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/21/26 8:05:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		District Hospital	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Shahum	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Lonar	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:15:15 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Bawan	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:15:14 PM	MVNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-II HARDOI (BAWAN)		Saityapur	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:14:23 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Manpur	33/11 KV S/5 Bawan	Scheduled Rostering	9453005113	05/22/26 3:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:14:23 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		EDD-2 BARABANKI (RAMNAGAR)	33/11 KV SUDHAYAMA	Emergency Rostering	8005489235	05/21/26 11:38:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:14:23 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Harsauli	33/11 KV SUDHAYAMA	Emergency Rostering	8005489235	05/21/26 11:38:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:14:23 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Sudhaimau	33/11 KV SUDHAYAMA	Emergency Rostering	8005489235	05/21/26 11:38:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:13:17 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Sara Dunauli feeder	33 kv men supply roting	Scheduled Rostering	9453005261	05/21/26 8:45:00 PM	2 H 0 M	Rostering
5/21/2026 9:13:17 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Hadaha Feeder	33 kv men supply roting	Scheduled Rostering	9453005261	05/21/26 8:45:00 PM	2 H 0 M	Rostering
5/21/2026 9:13:17 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		EDD-TIKAIT NAGAR	33 kv men supply roting	Scheduled Rostering	9453005261	05/21/26 12:03:00 AM	1 H 0 M	Rostering
5/21/2026 9:13:17 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-2 BARABANKI	EDDS-II BARABANKI (RAMNAGAR)		Sara Dunauli feeder	33 kv men supply roting	Scheduled Rostering	9453005261	05/22/26 12:03:00 AM	1 H 0 M	Rostering
5/21/2026 9:08:48 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I GAURIGANJ		मोर्छपुर	33/11 KV GAURIGANJ	Scheduled Rostering	7081387251	05/21/26 8:52:00 PM	0 H 45 M	Rostering
5/21/2026 9:08:48 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I GAURIGANJ		बरेठ	33/11 KV GAURIGANJ	Scheduled Rostering	7081387251	05/21/26 8:52:00 PM	0 H 45 M	Rostering
5/21/2026 9:08:48 PM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I GAURIGANJ		गाँव	33/11 KV GAURIGANJ	Scheduled Rostering	7081387251	05/21/26 8:52:00 PM	0 H 45 M	Rostering
5/21/2026 9:06:28 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMAU	EDDS-I SAPIPUR		SubSTATION	33 KV F841 Rostering from transmission	Emergency Rostering	800401293	05/21/26 12:25:00 AM	2 H 0 M	Transmission Rostering
5/21/2026 9:06:28 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMAU	EDDS-I SAPIPUR		DABULI	33 KV F841 Rostering from transmission	Emergency Rostering	800401293	05/22/26 12:25:00 AM	2 H 0 M	Transmission Rostering

BDSD REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	DEVIGANJ	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Maspora	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Sidhur	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Deviganj	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Hajipur	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Kojhar	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Subeha	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 8:46:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Maspora	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Sidhur	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Deviganj	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Kothi	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Hajipur	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:56:13 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HAIDERGARH	EDSD-DEVIGANJ	All 11 kv feeder open	Subeha	DEVIGANJ	Emergency Rostering	9453005263	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:53:49 PM	MVNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD AONLIA	EDSD-1 AONLIA	SARGAM ROAD	TOWN 1	33/11 KV MIRZAPUR	Breakdown Shutdown	8004918945	05/21/26 8:32:00 PM	0 H 30 M	11KV Line Fault
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD AONLIA	EDSD-1 AONLIA	SARGAM ROAD	Substation	33/11 KV MIRZAPUR	Breakdown Shutdown	8004918945	05/21/26 8:32:00 PM	0 H 30 M	11KV Line Fault
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD II AYODHYA MILKIPUR	EDSD-KUMARGANJ	MAAZGAWN	MAAZGAWN	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD II AYODHYA MILKIPUR	EDSD-KUMARGANJ	GHORWAL	GHORWAL	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:50:17 PM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKIPUR	EDSD-KUMARGANJ	KHMADASA	KHMADASA	33/11 Tulsum Pur	Emergency Rostering	9453007342	05/21/26 7:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:49:50 PM	MVNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-I GONDA	EDSD-I GONDA	हरमण्डल इलाके का बरखन करके शह क्षेत्र की फीडर समन्वित शह क्षेत्र उपप्लॉन करके	Kashiram	Avas Vikas Gonda	Breakdown Shutdown	9453007342	05/21/26 7:43:00 PM	0 H 32 M	DT Damaged/DT Fuse Burnt/Fire on DT
5/21/2026 8:44:50 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-I BARABANKI RAMNAGAR	EDSD-MASAUJI	Rampur Feeder	SHAHADATGANJ	33/11 KV MASAUJI	Breakdown Shutdown	9453005262	05/21/26 8:38:00 PM	0 H 20 M	DT Damaged/DT Fuse Burnt/Fire on DT
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	TERHA	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Scheduled Rostering	737992108	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	MALUNA KHERA	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Scheduled Rostering	737992108	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	TERHA	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Scheduled Rostering	737992108	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	PAALI	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Emergency Rostering	737992108	05/21/26 10:55:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	MALUNA KHERA	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Emergency Rostering	737992108	05/21/26 10:55:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:43:53 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-I PAATAN	TERHA	33/11 KV GIRIA NAGAR	33/11 KV GIRIA NAGAR	Emergency Rostering	737992108	05/21/26 10:55:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	MAURAWN	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	BHAWANPUR	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	AKORHI	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	SARGAUNJA	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	SUBSTATION	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:41:30 PM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	ROASTING MAURAWN RURAL	Bhawaniganj	33/11KV Maurawn	Scheduled Rostering	9453005039	05/21/26 8:35:00 PM	2 H 0 M	Rostering
5/21/2026 8:39:27 PM	MVNL	BAHARACH	DEVIPATAN	EDC-BAHARACH	EDD-II NANPARA	EDSD-IV MAHSI	THAHSSE	33/21 KV MAHSI THAHSSE	Emergency Rostering	9918813146	05/21/26 8:38:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:39:27 PM	MVNL	BAHARACH	DEVIPATAN	EDC-BAHARACH	EDD-II NANPARA	EDSD-IV MAHSI	TEHPANUR	33/21 KV MAHSI THAHSSE	Emergency Rostering	9918813146	05/21/26 8:38:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Harim Cold Store	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Swaistik Cold Store	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Urana	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Saidpur	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Barigaon	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Bhawanipur	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Chandauli	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:17 PM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAILU	EDSD-ASAPPUR	Papel	33/11 KV BAGRAIN	7830497089	05/21/26 8:34:00 PM	2 H 0 M	Rostering		
5/21/2026 8:39:15 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-FATEHPUR	KHINA	33/11 KV Badspur (Mallawa)	Emergency Rostering	8005489230	05/21/26 8:30:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:39:15 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-FATEHPUR	DWARIKA COLD STORAGE	Badspur	33/11 KV Badspur (Mallawa)	Emergency Rostering	8005489230	05/21/26 8:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	Babaganj	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 11:05:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	ATAHARA	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 11:05:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	DHAKURAHARA	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 11:05:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	Babaganj	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 8:32:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	ATAHARA	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 8:32:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:56 PM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-FATEHPUR	EDSD-I KURSI	DHAKURAHARA	33/11 KV BARAGANJ	Emergency Rostering	6389049333	05/21/26 8:32:00 PM	2 H 0 M	Transmission Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	TIKRI	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191	05/21/26 12:00:00 AM	0 H 40 M	Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	BARHAT	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191	05/21/26 12:00:00 AM	0 H 40 M	Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	BHUITA	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191	05/21/26 12:00:00 AM	0 H 40 M	Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	TIKRI	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191	05/21/26 6:15:00 PM	2 H 0 M	Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	SUMASHI	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191	05/21/26 6:15:00 PM	2 H 0 M	Rostering	
5/21/2026 8:38:36 PM	MVNL	PILIBHIT	BAREILLY-2	EDC-PILIBHIT	EDD-BISALPUR	EDSD-I BISALPUR	BHUITA	33/11 KV BARKHERA RURAL	Scheduled Rostering	9453005191</				

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 7:40:03 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHRAD	EDSD-SAWAYALPUR	RURAL	Pachewar	33/11 KV ANANGPUR	Scheduled Rostering	9453005099	05/21/26 10:45:00 PM	2 H 0 M	Rostering
5/21/2026 7:40:01 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR		SOUTH WEST	33/11 KV BIKAPUR RURAL	Emergency Rostering	9453007337	05/21/26 7:39:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:40:01 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR		NORTH EAST FEEDER	33/11 KV BIKAPUR RURAL	Emergency Rostering	9453007337	05/21/26 7:39:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:40:01 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR		KLK FEEDER	33/11 KV BIKAPUR RURAL	Emergency Rostering	9453007337	05/21/26 7:39:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:40:01 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR		SOUTH FEEDER	33/11 KV BIKAPUR RURAL	Emergency Rostering	9453007337	05/21/26 7:39:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:40:01 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR		S.E. FEEDER	33/11 KV BIKAPUR RURAL	Emergency Rostering	9453007337	05/21/26 7:39:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:39:56 PM	MWNL	RAEBARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDSD-LALGANJ		Jalwaj	33/11 KV BEHTA RAEBARELI	Emergency Rostering	800415985	05/21/26 9:00:00 AM	1 H 13 30 M	11KV Line Fault
5/21/2026 7:39:56 PM	MWNL	RAEBARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDSD-LALGANJ	फौर बैरभञ्जन ठो जामे के सरकर फौर रमनाफिर होर की अमरुती बाहिर हे फौर बैरभञ्जन ठो जामे के सरकर फौर रमनाफिर होर की अमरुती बाहिर हे	Champak Pur	33/11 KV BEHTA RAEBARELI	Breakdown Shutdown	800415985	05/21/26 9:00:00 AM	1 H 13 30 M	11KV Line Fault
5/21/2026 7:39:56 PM	MWNL	RAEBARELI	RAEBARELI	EDC-2 RAEBARELI	EDD-3 LALGANJ	EDSD-LALGANJ	फौर बैरभञ्जन ठो जामे के सरकर फौर रमनाफिर होर की अमरुती बाहिर हे फौर बैरभञ्जन ठो जामे के सरकर फौर रमनाफिर होर की अमरुती बाहिर हे	AANAPUR	33/11 KV BEHTA RAEBARELI	Breakdown Shutdown	800415985	05/21/26 9:00:00 AM	1 H 13 30 M	11KV Line Fault
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Naral	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/21/26 7:37:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		paraka	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/21/26 7:37:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv chanda pur	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/21/26 7:37:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv Hardoi	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/21/26 7:37:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Deppamu	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/21/26 7:37:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Nara	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		paraka	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv chanda pur	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv Hardoi	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Deppamu	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Nara	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		paraka	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv chanda pur	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		11 kv Hardoi	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Deppamu	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:36 PM	MWNL	RAEBARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-MAHARAIGANJ	EDSD-MAHARAIGANJ		Nara	Maharaj Ganj Rural	Emergency Rostering	9453005002	05/22/26 5:29:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 7:38:35 PM	MWNL	BUDANJ	BAREILLY-2	EDC-BADUANJ	EDD-UJHANI	EDSD-UJHANI		Town III	33/11 KV UJHANI TOWN	Emergency Rostering	7599560248	05/21/26 8:01:00 PM	1 H 1 M	Overloading
5/21/2026 7:38:35 PM	MWNL	BUDANJ	BAREILLY-2	EDC-BADUANJ	EDD-UJHANI	EDSD-UJHANI		Town II	33/11 KV UJHANI TOWN	Emergency Rostering	7599560248	05/21/26 7:38:00 PM	1 H 1 M	Overloading
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-PALIA	EDD-PALIA	EDSD-PALIA		station road	33/11 KV S/5 PALIA TASHSEL	Breakdown Shutdown	9453005091	05/21/26 7:35:00 PM	0 H 0 M	LT/ARC Line Fault
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA		bankara	33/11 KV S/5 PALIA TASHSEL	Scheduled Rostering	9453005091	05/21/26 9:55:00 PM	1 H 0 M	Rostering
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA		station road	33/11 KV S/5 PALIA TASHSEL	Scheduled Rostering	9453005091	05/21/26 9:55:00 PM	1 H 0 M	Rostering
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA		tehra	33/11 KV S/5 PALIA TASHSEL	Scheduled Rostering	9453005091	05/21/26 9:55:00 PM	1 H 0 M	Rostering
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA		DHAINI	33/11 KV S/5 PALIA TASHSEL	Scheduled Rostering	9453005091	05/21/26 9:55:00 PM	1 H 0 M	Rostering
5/21/2026 7:38:27 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-PALIA	EDD-PALIA	EDSD-PALIA		SUBSTATION	33/11 KV S/5 PALIA TASHSEL	Scheduled Rostering	9453005091	05/21/26 9:55:00 PM	1 H 0 M	Rostering
5/21/2026 7:36:41 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-1 HARDOI	EDSD-BILGRAM		Sadriya pur	33/11 KV CHHIBRAMAU HARDOI	Scheduled Rostering	9450909991	05/22/26 5:00:00 AM	1 H 0 M	Rostering
5/21/2026 7:36:41 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-1 HARDOI	EDSD-BILGRAM		Chibramau	33/11 KV CHHIBRAMAU HARDOI	Scheduled Rostering	9450909991	05/22/26 5:00:00 AM	1 H 0 M	Rostering
5/21/2026 7:36:41 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-1 HARDOI	EDSD-BILGRAM		Ataricha	33/11 KV CHHIBRAMAU HARDOI	Scheduled Rostering	9450909991	05/22/26 5:00:00 AM	1 H 0 M	Rostering
5/21/2026 7:36:41 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-1 HARDOI	EDSD-BILGRAM		Ataricha	33/11 KV CHHIBRAMAU HARDOI	Scheduled Rostering	9450909991	05/21/26 7:20:00 PM	2 H 0 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		BHOCHI	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/21/26 7:35:00 PM	2 H 15 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		DEVASRA	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/21/26 7:35:00 PM	2 H 15 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		MAHUPUR BAZAR	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/21/26 7:35:00 PM	2 H 15 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		BHADODHI	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/22/26 12:30:00 AM	2 H 0 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		DEVASRA	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/22/26 12:30:00 AM	2 H 0 M	Rostering
5/21/2026 7:36:10 PM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-JALALPUR		MAHUPUR BAZAR	33/11 KV MALPUR	Scheduled Rostering	9151643270	05/22/26 12:30:00 AM	2 H 0 M	Rostering
5/21/2026 7:34:48 PM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD II BARABANKI RAMNAGAR	EDSD-MASAUJI	All masauli sub station	MASAUJI	33/11 KV MASAUJI	Emergency Rostering	9453005262	05/21/26 6:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:34:48 PM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD II BARABANKI RAMNAGAR	EDSD-MASAUJI	All masauli sub station	BAANSA	33/11 KV MASAUJI	Emergency Rostering	9453005262	05/21/26 6:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:34:48 PM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD II BARABANKI RAMNAGAR	EDSD-MASAUJI	All masauli sub station	ZAKARIA	33/11 KV MASAUJI	Emergency Rostering	9453005262	05/21/26 6:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:30:26 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	SANADATGANJ	33/11 KV MASAUJI	Emergency Rostering	9453005262	05/21/26 6:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:30:26 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	Pahadpur	33/11 KV MASAUJI	Emergency Rostering	7318095324	05/21/26 7:20:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:30:26 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	Ram Nagar	Gauriganj	Emergency Rostering	7318095324	05/21/26 7:20:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:30:26 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	KALIHAR	Gauriganj	Emergency Rostering	7318095324	05/21/26 7:20:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:27:45 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	BERNATIKAR	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 7:27:45 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	BERNATIKAR	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 7:27:45 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ (Amethi)	EDSD-GAURIGANJ (Amethi)	All masauli sub station	रेशी	BERNATIKAR	Scheduled Rostering	7081387251	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	COUDNY	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	NAUGAVANM	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	CHAIKUDA	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	MAHIGAI	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	COUDNY	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	NAUGAVANM	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	Rostering
5/21/2026 7:27:14 PM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	all	CHAIKUDA	33/11 KV S/5 MAHIGAI	Scheduled Rostering	9453012573	05/21/26 6:15:00 PM	0 H 40 M	

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 7:20:29 PM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-LAKHIMPUR	EDD-III Lakhimpur (NIGHASAN)	EDSD-I NIGHASAN		BARWI	33/11 KV S/S Nighasan	Emergency Rostering	9453005076	05/21/26 7:19:00 PM	2 H 20 M	Transmission Rostering
5/21/2026 7:20:29 PM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-LAKHIMPUR	EDD-III Lakhimpur (NIGHASAN)	EDSD-I NIGHASAN		CHAHARAHA	33/11 KV S/S NIGHASAN	Emergency Rostering	9453005076	05/21/26 7:19:00 PM	2 H 30 M	Transmission Rostering
5/21/2026 7:20:29 PM	MWNL	AMBEDKAR NAGAR (AKBARPUR)	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-NEWADA (JALALPUR)		Rafganj	33/11 KV RAFGANJ	Scheduled Rostering	9453005220	05/21/26 7:19:00 PM	2 H 0 M	Rostering
5/21/2026 7:20:29 PM	MWNL	AMBEDKAR NAGAR (AKBARPUR)	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-NEWADA (JALALPUR)		marhara	33/11 KV RAFGANJ	Scheduled Rostering	9453005220	05/21/26 7:19:00 PM	2 H 0 M	Rostering
5/21/2026 7:20:29 PM	MWNL	AMBEDKAR NAGAR (AKBARPUR)	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-NEWADA (JALALPUR)		Semra	33/11 KV RAFGANJ	Scheduled Rostering	9453005220	05/21/26 7:19:00 PM	0 H 45 M	Rostering
5/21/2026 7:20:29 PM	MWNL	AMBEDKAR NAGAR (AKBARPUR)	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-NEWADA (JALALPUR)		Rafganj	33/11 KV RAFGANJ	Scheduled Rostering	9453005220	05/21/26 7:19:00 PM	0 H 45 M	Rostering
5/21/2026 7:20:29 PM	MWNL	AMBEDKAR NAGAR (AKBARPUR)	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALALPUR	EDSD-NEWADA (JALALPUR)		marhara	33/11 KV RAFGANJ	Scheduled Rostering	9453005220	05/21/26 7:19:00 PM	0 H 45 M	Rostering
5/21/2026 7:18:31 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAB	EDSD-SHAHAB		Shahabad Tehsil	33/11 KV Shahabad Tehsil	Planned Shutdown	8005490437	05/21/26 7:17:00 PM	0 H 15 M	DT Maintenance
5/21/2026 7:18:05 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		Rasulabad	Karpiya	Emergency Rostering	7318095317	05/21/26 7:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:18:05 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		SARAIYA VISHOYAN	Karpiya	Emergency Rostering	7318095317	05/21/26 7:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:18:05 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		Rasulabad	Karpiya	Emergency Rostering	7318095317	05/21/26 7:15:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 7:18:05 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		SARAIYA VISHOYAN	Karpiya	Emergency Rostering	7318095317	05/21/26 7:15:00 PM	3 H 0 M	Transmission Rostering
5/21/2026 7:18:05 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		Jamruiya	Karpiya	Emergency Rostering	7318095317	05/21/26 7:15:00 PM	3 H 0 M	Transmission Rostering
5/21/2026 7:17:03 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		radh Pump khalai	33/11 KV MAHONA	Scheduled Rostering	9454998984	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 7:17:03 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA		33KV Mahona	33/11 KV MAHONA	Scheduled Rostering	9454998984	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 7:14:08 PM	MWNL	LUCKNOW	AMAUJI	LUCKNOW RURAL	EDD-MOHANALGANJ	EDSD-MOHANALGANJ		maharana ke aage band hai	UPA-I	Breakdown Shutdown	8004921270	05/21/26 2:38:00 PM	4 H 10 M	11KV Line Fault
5/21/2026 7:10:14 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		palpur Rudauli Feeder	Rudauli	Tripping	9453005267	05/21/26 7:00:00 PM	5 H 5 M	Other Transient Fault
5/21/2026 7:10:14 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		palpur	33/11 KV PATRANGA	Tripping	9453005267	05/21/26 7:00:00 PM	5 H 5 M	Other Transient Fault
5/21/2026 7:06:41 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		palpur	33/11 KV PATRANGA	Planned Shutdown	9453005267	05/21/26 1:50:00 PM	1 H 0 M	Line maintenance
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Purani Khurd	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		New Khurd	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Haridaspur	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		SUKATA	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		shipurai rural (ag)	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		SRODUJ RURAL	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		HARDASPUR RURAL AG	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		SRODUJ RURAL AG	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Chukatiya Dehat	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:04:07 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Shipurai	33/11 KV BARSER	Scheduled Rostering	8004918950	05/21/26 7:03:00 PM	2 H 0 M	Rostering
5/21/2026 7:03:53 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		Rudauli	33/11 KV PATRANGA	Tripping	9453005267	05/21/26 1:45:00 PM	0 H 5 M	Other Transient Fault
5/21/2026 7:03:53 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		Palpur	33/11 KV PATRANGA	Tripping	9453005267	05/21/26 1:45:00 PM	0 H 5 M	Other Transient Fault
5/21/2026 7:00:08 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		PATRANGA	33/11 KV PATRANGA	Tripping	9453005267	05/21/26 12:50:00 PM	0 H 5 M	Other Transient Fault
5/21/2026 7:00:07 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAJLI	EDSD-PATRANGA		Patranga Feeder all area	Patranga	Tripping	9453005267	05/21/26 12:50:00 PM	0 H 5 M	Other Transient Fault
5/21/2026 6:59:22 PM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-4 MANKAPUR	EDSD-I DHANEPUR		10MVA का ट्रांसफार्मर ओवरलोडिंग होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	Balrampur	Emergency Rostering	8005494335	05/21/26 6:30:00 PM	23 H 59 M	Overloading
5/21/2026 6:59:22 PM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-4 MANKAPUR	EDSD-I DHANEPUR		10MVA का ट्रांसफार्मर ओवरलोडिंग होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	Patal Pump	Emergency Rostering	8005494335	05/21/26 6:30:00 PM	23 H 59 M	Overloading
5/21/2026 6:59:22 PM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-4 MANKAPUR	EDSD-I DHANEPUR		10MVA का ट्रांसफार्मर ओवरलोडिंग होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	East	Emergency Rostering	8005494335	05/21/26 6:30:00 PM	23 H 59 M	Overloading
5/21/2026 6:59:22 PM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-4 MANKAPUR	EDSD-I DHANEPUR		10MVA का ट्रांसफार्मर ओवरलोडिंग होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	Substation	Emergency Rostering	8005494335	05/21/26 6:30:00 PM	23 H 59 M	Overloading
5/21/2026 6:58:23 PM	MWNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-I IKAUNA		33 KV फेडर काउंड केवल केकस्टन होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	Substation	Emergency Rostering	9453005231	05/21/26 10:00:00 AM	10 H 0 M	33KV Line Fault
5/21/2026 6:58:23 PM	MWNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-I IKAUNA		33 KV फेडर काउंड केवल केकस्टन होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	OPSPITAL	Breakdown Shutdown	9453005231	05/21/26 10:00:00 AM	10 H 0 M	33KV Line Fault
5/21/2026 6:58:23 PM	MWNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-I IKAUNA		33 KV फेडर काउंड केवल केकस्टन होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	kauna	Breakdown Shutdown	9453005231	05/21/26 10:00:00 AM	10 H 0 M	33KV Line Fault
5/21/2026 6:58:23 PM	MWNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-I IKAUNA		33 KV फेडर काउंड केवल केकस्टन होने के कारण फीडर सम्बन्धित क्षेत्र की सप्लाई 2	Shrawaha Maidan	Breakdown Shutdown	9453005231	05/21/26 10:00:00 AM	10 H 0 M	33KV Line Fault
5/21/2026 6:57:04 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Jarsani	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:04 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Ugalyi Town	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:04 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Chauki Khilaura	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:04 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Dara Nagar	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:04 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Islan Nagar	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:03 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Titalu (rural)	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:57:03 PM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-II ISLAMNAGAR		substation	Nagarjya Fort	Emergency Rostering	8954432967	05/21/26 6:15:00 PM	2 H 15 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		EDD-2 DEORANIA	EDD-BARHER	Emergency Rostering	8005494500	05/21/26 10:00:00 AM	1 H 30 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		HARDASPUR PNPR RURAL	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Gaurishanker	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Hardaspur Gramen	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		PTM	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Ganeshpur	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:49:18 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-AONLA	EDSD-III AONLA		Gaurishanker Guladiya	33/11 KV PUNNAPUR	Emergency Rostering	8004918679	05/21/26 6:48:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	BESU-1	Breakdown Shutdown	8171574977	05/21/26 6:45:00 PM	3 H 0 M	33KV Line Fault
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	SHASTRI NAGAR	Breakdown Shutdown	8171574977	05/21/26 6:45:00 PM	3 H 0 M	33KV Line Fault
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	EDD-3 BAREILLY	Breakdown Shutdown	8171574977	05/21/26 6:45:00 PM	3 H 0 M	33KV Line Fault
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	M.L NAGAR	Breakdown Shutdown	8171574977	05/21/26 6:45:00 PM	3 H 0 M	33KV Line Fault
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	BESU-2	Breakdown Shutdown	8171574977	05/21/26 6:45:00 PM	3 H 0 M	33KV Line Fault
5/21/2026 6:46:35 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EUDD-3 BAREILLY	EDSD-6 RAENDRA NAGAR		Izzatnagar	Jail Road	Breakdown Shutdown	8171574977	05/21/26 6		

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 6:16:03 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHRI	EDSD-2 DEORANIA	devaranya	Sharif nagar	33/11 KV DEORANIA	Breakdown Shutdown	8004918689	05/21/26 6:00:00 AM	2 H 40 M	33KV Line Fault
5/21/2026 6:16:03 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHRI	EDSD-2 DEORANIA	devaranya	Ahermadabad	33/11 KV DEORANIA	Breakdown Shutdown	8004918689	05/21/26 6:00:00 AM	2 H 40 M	33KV Line Fault
5/21/2026 6:16:03 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-BAHRI	EDSD-2 DEORANIA	devaranya	SURBATOWN	33/11 KV DEORANIA	Breakdown Shutdown	8004918689	05/21/26 6:00:00 AM	2 H 40 M	33KV Line Fault
5/21/2026 6:15:51 PM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	World bank	PAITEPUR	33/11 KV MAHMOODABAD (RURAL)	Emergency Rostering	9453005062	05/21/26 6:14:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:15:51 PM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	World bank	PAITEPUR	33/11 KV MAHMOODABAD (RURAL)	Emergency Rostering	9453005062	05/21/26 6:14:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:15:51 PM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	World bank	PAITEPUR	33/11 KV MAHMOODABAD (RURAL)	Emergency Rostering	9453005062	05/21/26 6:14:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:10:33 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAULI	EDSD-SOHAVAL	11 kv suchitta ganj gramen	Suchitganj	9453005211	05/21/26 6:05:00 PM	0 H 25 M	DT Maintenance		
5/21/2026 6:09:59 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDSD-III MOHAMMADI	SHukhsua	33/11 KV SUKHWASA	Planned Shutdown	7607103855	05/21/26 6:09:00 PM	0 H 15 M	Line maintenance	
5/21/2026 6:04:19 PM	MWNL	LUCKNOW	LUCKNOW CENTRAL	EDC-LUCKNOW	EDD-UPFRONT	EDSD-UPFRONT	हलिकापुर सेक्टर रिडर मस्जिदपुर Pakkabah रिंग क्षेत्र कनक सिटी	HABIBPUR	UPFRONT	Planned Shutdown	8004912247	05/21/26 6:03:00 PM	0 H 13 M	Line maintenance
5/21/2026 6:04:05 PM	MWNL	LUCKNOW	LUCKNOW CENTRAL	EDC-LUCKNOW	EDD-CHOWK	EDSD-CHOWK	NADAN MASRI	Nanak Nagar	Planned Shutdown	8887158601	05/21/26 5:57:00 PM	0 H 13 M	Line maintenance	
5/21/2026 5:57:04 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMUJ	EDSD-II SAIPUR	33 kv saipur rural roasting from transmission	DABULI	FATEHPUR CHAUHARI NEW	Breakdown Shutdown	8004001293	05/21/26 5:54:00 PM	0 H 30 M	11KV Line Fault
5/21/2026 5:53:55 PM	MWNL	UNNAO	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	gundhura	NORTH EAST FEEDER	9453007337	05/21/26 5:45:00 PM	0 H 20 M	Line maintenance		
5/21/2026 5:53:36 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-1 UNNAO	EDSD-BICHHIYA	11 kv सान्दान चक्रेट होने के कारण ट्रान्स्फोर्मर संचालनित होने की अपूर्णता बाहिर है	Bichhya	33/11 KV BICHHIYA	Breakdown Shutdown	9415901269	05/21/26 1:00:00 PM	5 H 18 M	11KV Line Fault
5/21/2026 5:53:36 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-1 UNNAO	EDSD-BICHHIYA	11 kv सान्दान चक्रेट होने के कारण ट्रान्स्फोर्मर संचालनित होने की अपूर्णता बाहिर है	PADRI	33/11 KV BICHHIYA	Emergency Rostering	9415901269	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 5:53:36 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-1 UNNAO	EDSD-BICHHIYA	11 kv सान्दान चक्रेट होने के कारण ट्रान्स्फोर्मर संचालनित होने की अपूर्णता बाहिर है	lagaa	33/11 KV BICHHIYA	Emergency Rostering	9415901269	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 5:53:36 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-1 UNNAO	EDSD-BICHHIYA	11 kv सान्दान चक्रेट होने के कारण ट्रान्स्फोर्मर संचालनित होने की अपूर्णता बाहिर है	Bichhya	33/11 KV BICHHIYA	Emergency Rostering	9415901269	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 5:53:36 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-1 UNNAO	EDSD-BICHHIYA	11 kv सान्दान चक्रेट होने के कारण ट्रान्स्फोर्मर संचालनित होने की अपूर्णता बाहिर है	Taura	33/11 KV BICHHIYA	Emergency Rostering	9415901269	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 5:50:28 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMUJ	EDSD-II SAIPUR	33 kv saipur rural roasting from transmission	11 KV PARIYAR	SAFUPUR SUBSTATION	Breakdown Shutdown	9453007434	05/21/26 3:20:00 PM	1 H 20 M	11KV Line Fault
5/21/2026 5:50:28 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMUJ	EDSD-II SAIPUR	33 kv saipur rural roasting from transmission	11 KV ASWAN	SAFUPUR SUBSTATION	Emergency Rostering	9453007434	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 5:48:56 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMUJ	EDSD-III TAKIYA	EDSD-III TAKIYA	ASHA KHEDA	FATEHPUR CHAUHARI (TAKIYA)	Breakdown Shutdown	9415901268	05/21/26 5:47:00 PM	1 H 10 M	11KV Line Fault
5/21/2026 5:48:28 PM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-5 HASANGANJ	EDSD-NAWAABGANJ (AUGAIN)	roasting	BANI KHEDA	33/11 KV SOHRA MAU	Scheduled Rostering	9415909939	05/21/26 1:00:00 PM	1 H 15 M	Rostering
5/21/2026 5:43:25 PM	MWNL	RAE BARELI	RAEBARELI-1	EDC-RAEBARELI	EDD-UNLACHHAR	EDSD-UNLACHHAR	Kivvaha	Jamrugar	33/11 KV UNLACHHAR	Breakdown Shutdown	8398132041	05/21/26 12:00:00 AM	23 H 59 M	Transmission Rostering
5/21/2026 5:43:25 PM	MWNL	RAE BARELI	RAEBARELI-2	EDC-RAEBARELI	EDD-UNLACHHAR	EDSD-UNLACHHAR	Jamrugar	Jamrugar	33/11 KV UNLACHHAR	Breakdown Shutdown	8398237041	05/21/26 12:00:00 AM	23 H 59 M	11KV Line Fault
5/21/2026 5:33:56 PM	MWNL	LUCKNOW	LUCKNOW CENTRAL	EDC-CHOWK	EDD-RESIDENCY	EDSD-RESIDENCY	UPLI	A P SEN ROAD	8004921220	05/21/26 5:31:00 PM	0 H 15 M	11KV Line Fault		
5/21/2026 5:31:04 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-1 AYODHYA	EDSD-AYODHYA	AYODHYA	Saket P.G.College	9453005399	05/21/26 5:09:00 PM	0 H 30 M	11KV Line Fault		
5/21/2026 5:23:03 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	KAMTA	630 kVA transformer open kar ko chalu karayi baki yah Transformer 1 ghante mein chal	ULMAL NAGAR	Breakdown Shutdown	8005493992	05/21/26 5:17:00 PM	1 H 30 M	DT Damaged/OT Fuse Burnt/Fire on DT
5/21/2026 5:23:03 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	KAMTA	630 kVA transformer open kar ko chalu karayi baki yah Transformer 1 ghante mein chal	ULMAL NAGAR	Breakdown Shutdown	8005493992	05/21/26 5:17:00 PM	1 H 30 M	DT Damaged/OT Fuse Burnt/Fire on DT
5/21/2026 5:14:40 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	Madina	Pura basar	9453009219	05/21/26 10:14:00 AM	10 H 0 M	33KV Line Fault		
5/21/2026 5:14:40 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	Madina	Pura basar	8004922192	05/21/26 7:40:00 PM	2 H 0 M	Rostering		
5/21/2026 5:14:40 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	Madina	Pura basar	8004922192	05/21/26 7:40:00 PM	2 H 0 M	Rostering		
5/21/2026 5:14:40 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	Madina	Pura basar	8004922192	05/21/26 7:40:00 PM	2 H 0 M	Rostering		
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	राजा साहजिद फौज चक्रेट कोर्टो जमेट गैरट येन गैरट जाइजमजिदगंज के चक्रेट कोर्टो	BRUKA SATRIKH	33/11 KV PALUHARI NEW	Planned Shutdown	9453005164	05/21/26 5:00:00 PM	0 H 45 M	Line maintenance
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Pali	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Hawal Patti	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Khandhar	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Dahana	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Madnagar	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Apattiyaur	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:35 PM	MWNL	SHAHJAHANPUR	BAREILLY-2	EDC-SHAHJAHANPUR	EDD-JALALABAD	EDSD-JALALABAD	11 kv रीस्टिंग होने के कारण सभी क्षेत्र की अपूर्णता बाहिर है	Raghnathpur	JALALABAD Rural	Scheduled Rostering	9453005144	05/21/26 2:00:00 PM	4 H 0 M	Rostering
5/21/2026 5:05:33 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAULI	EDSD-SOHAVAL	11 kv suchitta ganj gramin	Suchitganj	33/11 KV SOHAVAL	Planned Shutdown	9453005211	05/21/26 4:50:00 PM	0 H 35 M	DT Maintenance
5/21/2026 5:03:31 PM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSD-I BAHRAICH	BAHRAICH	BASHIR GANJ	33/11 KV MAHGAJ	Breakdown Shutdown	8004793109	05/21/26 5:03:00 PM	3 H 0 M	11KV Line Fault
5/21/2026 5:03:31 PM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSD-I BAHRAICH	BAHRAICH	BANARI MOD	BASHIR GANJ	Breakdown Shutdown	8004793109	05/21/26 5:02:00 PM	3 H 0 M	11KV Line Fault
5/21/2026 5:03:31 PM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSD-I BAHRAICH	BAHRAICH	BAHAR GANJ	33/11 KV MAHGAJ	Breakdown Shutdown	8004793109	05/21/26 5:02:00 PM	3 H 0 M	11KV Line Fault
5/21/2026 5:03:31 PM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSD-I BAHRAICH	BAHRAICH	BASHIR GANJ	33/11 KV MAHGAJ	Breakdown Shutdown	8004793109	05/21/26 5:02:00 PM	3 H 0 M	11KV Line Fault
5/21/2026 5:03:31 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	AIJI	COLONY	33/11 KV S/5 MAHGAJ	Scheduled Rostering	9453012573	05/21/26 4:54:00 PM	2 H 35 M	Rostering
5/21/2026 5:03:31 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	AIJI	NEWRA	33/11 KV S/5 MAHGAJ	Scheduled Rostering	9453012573	05/21/26 4:54:00 PM	2 H 35 M	Rostering
5/21/2026 5:03:31 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	AIJI	CHAUDKA	33/11 KV S/5 MAHGAJ	Scheduled Rostering	9453012573	05/21/26 4:54:00 PM	2 H 35 M	Rostering
5/21/2026 5:03:31 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	AIJI	MAHGAJ	33/11 KV S/5 MAHGAJ	Scheduled Rostering	9453012573	05/21/26 4:54:00 PM	2 H 35 M	Rostering
5/21/2026 5:03:31 PM	MWNL	Lakhipur KHRI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	majhaji	MAHGAJ	33/11 KV S/5 MAHGAJ	Breakdown Shutdown	9453012573	05/21/26 4:58:00 PM	3 H 10 M	11KV Line Fault
5/21/2026 4:40:42 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-GAURIGANJ	AYODHYA	NARAYANPUR	33/11 KV MAU	Breakdown Shutdown	7318095321	05/21/26 4:30:00 PM	0 H 10 M	117ABC Line Fault
5/21/2026 4:40:42 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-GAURIGANJ	AYODHYA	GOPALPUR	33/11 KV MAU	Scheduled Rostering	7318095321	05/21/26 4:30:00 PM	2 H 0 M	Rostering
5/21/2026 4:40:42 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-GAURIGANJ	AYODHYA	NARAYANPUR	33/11 KV MAU	Scheduled Rostering	7318095321	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 4:40:42 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-GAURIGANJ	AYODHYA	MAU	33/11 KV MAU	Scheduled Rostering	7318095321	05/21/26 7:15:00 PM	2 H 0 M	Rostering
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	CROWN MALL	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	SPRING GARDEN	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	Omaga-1	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	Omaga-2	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	Omaga-3	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	Omaga-4	OMEGA GREEN	Planned Shutdown	8004910733	05/21/26 4:37:00 PM	1 H 2 M	Line maintenance
5/21/2026 4:39:31 PM	MWNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTI NAGAR	EDD-CINHNAT	EDSD-CINHNAT	CHINHNAT	Omaga-5	OMEGA GREEN	Pl				

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 4:03:15 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-GOSHANGANI		MAHBOOBGANJ	33/11 KV DILASGANJ	Breakdown Shutdown	9453035536	05/21/26 9:25:00 AM	3 H 0 M	11KV Line Fault
5/21/2026 4:03:15 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-GOSHANGANI		BILASHINGANJ	33/11 KV DILASGANJ	Emergency Rostering	9453035536	05/22/26 1:00:00 AM	2 H 0 M	Transmission Rostering
5/21/2026 4:02:44 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-GOSHANGANI		MAHBOOBGANJ	33/11 KV DILASGANJ	Emergency Rostering	9453035536	05/21/26 3:30:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 3:55:16 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BAKARGANJ	all 11kv feeder	Bhadrasa	MASHODHA	Emergency Rostering	9453007335	05/21/26 10:52:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 3:55:15 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BAKARGANJ	all 11kv feeder	BHARATKUND	MASHODHA	Emergency Rostering	9453007335	05/21/26 10:52:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 3:55:15 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BAKARGANJ	Arcwawa 100kva tf	BIKRAUL	MASHODHA	Emergency Rostering	9453007335	05/21/26 10:52:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 3:53:20 PM	MWNL	BAHRAICH	DEVIPATAN	EDC-BAHRAICH	EDD-3 BAHRAICH (KAISERGANJ)	EDDS-IV-Pyagpur	11 kv रीस्टिंग होने के कारण क्षेत्र की आपूर्ति बाधित है	Khuteha	Pyagpur	Scheduled Rostering	9452323469	05/21/26 2:00:00 PM	2 H 30 M	Rostering
5/21/2026 3:53:20 PM	MWNL	BAHRAICH	DEVIPATAN	EDC-BAHRAICH	EDD-3 BAHRAICH (KAISERGANJ)	EDDS-IV-Pyagpur	11 kv रीस्टिंग होने के कारण क्षेत्र की आपूर्ति बाधित है	Visheshwar gani	Pyagpur	Scheduled Rostering	9452323469	05/21/26 2:00:00 PM	2 H 30 M	Rostering
5/21/2026 3:53:20 PM	MWNL	BAHRAICH	DEVIPATAN	EDC-BAHRAICH	EDD-3 BAHRAICH (KAISERGANJ)	EDDS-IV-Pyagpur	11 kv रीस्टिंग होने के कारण क्षेत्र की आपूर्ति बाधित है	Pyagpur Rural	Pyagpur	Scheduled Rostering	9452323469	05/21/26 2:00:00 PM	2 H 30 M	Rostering
5/21/2026 3:51:22 PM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDDS-PALIA	station road	33/11 KV S/5 PALIA THASEL	Breakdown Shutdown	9453005091	05/21/26 3:41:00 PM	0 H 10 M	Power Transformer Fault	
5/21/2026 3:51:22 PM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDDS-PALIA	station road	33/11 KV S/5 PALIA THASEL	Breakdown Shutdown	9453005091	05/21/26 5:23:00 PM	0 H 30 M	Power Transformer Fault	
5/21/2026 3:49:21 PM	MWNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-DUBAGGA	EDDS-DUBAGGA	केच पॉवरले होने के कारण क्षेत्र सम्बन्धित कुछ क्षेत्र की आपूर्ति बाधित है	Jehta	33/11 KV AMRAPALI DUBAGGA (OLD)	Breakdown Shutdown	8004921275	05/21/26 7:00:00 AM	9 H 48 M	LT/ABC Line Fault
5/21/2026 3:49:21 PM	MWNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-DUBAGGA	EDDS-DUBAGGA	केच पॉवरले होने के कारण क्षेत्र सम्बन्धित कुछ क्षेत्र की आपूर्ति बाधित है	Fadev Bazar	33/11 KV AMRAPALI DUBAGGA (OLD)	Breakdown Shutdown	8004921275	05/21/26 7:00:00 AM	9 H 48 M	LT/ABC Line Fault
5/21/2026 3:49:11 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDDS-PHANI	Abdulla Nagar	33/11 KV S/5 Rabha	Planned Shutdown	9684400670	05/21/26 3:45:00 PM	0 H 30 M	DT Maintenance	
5/21/2026 3:49:11 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDDS-PHANI	Rabha	33/11 KV S/5 Rabha	Planned Shutdown	9684400670	05/21/26 3:45:00 PM	0 H 30 M	DT Maintenance	
5/21/2026 3:49:11 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDDS-PHANI	Rabha	33/11 KV S/5 Rabha	Planned Shutdown	9684400670	05/21/26 3:45:00 PM	0 H 30 M	DT Maintenance	
5/21/2026 3:45:51 PM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDDS-IV BARABANKI TOWN	masa feeder all areas	MAJIA	J.P.NAGAR	Breakdown Shutdown	9453005244	05/21/26 7:30:00 PM	1 H 5 M	11KV Line Fault
5/21/2026 3:45:03 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-III AYODHYA MILKUPUR	EDDS-RANI BAZAR	KANDALIA	RANIBAZAR	Breakdown Shutdown	9453007336	05/21/26 3:30:00 PM	1 H 0 M	11KV Line Fault	
5/21/2026 3:42:29 PM	MWNL	BAKRAMPUR	DEVIPATAN	EDC-BAKRAMPUR	EDD-TULSIPUR	EDDS-HARARAYA SATGHARWA	रीस्टिंग होने के कारण क्षेत्र सम्बन्धित कुछ क्षेत्र की आपूर्ति बाधित है	Kondalibagh	TULSIPUR RURAL	Scheduled Rostering	9129241700	05/21/26 3:35:00 PM	2 H 45 M	Rostering
5/21/2026 3:42:29 PM	MWNL	BAKRAMPUR	DEVIPATAN	EDC-BAKRAMPUR	EDD-TULSIPUR	EDDS-HARARAYA SATGHARWA	रीस्टिंग होने के कारण क्षेत्र सम्बन्धित कुछ क्षेत्र की आपूर्ति बाधित है	Kondalibagh	TULSIPUR RURAL	Scheduled Rostering	9129241700	05/21/26 3:35:00 PM	2 H 45 M	Rostering
5/21/2026 3:42:29 PM	MWNL	BAKRAMPUR	DEVIPATAN	EDC-BAKRAMPUR	EDD-TULSIPUR	EDDS-HARARAYA SATGHARWA	रीस्टिंग होने के कारण क्षेत्र सम्बन्धित कुछ क्षेत्र की आपूर्ति बाधित है	World Bank	TULSIPUR RURAL	Scheduled Rostering	9129241700	05/21/26 3:35:00 PM	2 H 45 M	Rostering
5/21/2026 3:31:31 PM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-KADIPUR	EDDS-KADIPUR	33kv	KADIPUR THASEL FEEDER No-2	Kadipur thaseel	Breakdown Shutdown	9151997122	05/21/26 3:23:00 PM	1 H 0 M	33KV Line Fault
5/21/2026 3:31:31 PM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-KADIPUR	EDDS-KADIPUR	33kv	KADIPUR	Kadipur thaseel	Breakdown Shutdown	9151997122	05/21/26 3:23:00 PM	1 H 0 M	33KV Line Fault
5/21/2026 3:31:31 PM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-KADIPUR	EDDS-KADIPUR	33kv	Feeder No-3	Kadipur thaseel	Breakdown Shutdown	9151997122	05/21/26 3:23:00 PM	1 H 0 M	33KV Line Fault
5/21/2026 3:30:02 PM	MWNL	LAKHIMPUR	AYODHYA	EDC-GOMTINAGAR	EDD-KADIPUR	EDDS-KADIPUR	KHAY KHAND JIYARIYAN	GOMTI NAGAR	KADIPUR THASEL	Planned Shutdown	8004921238	05/21/26 3:05:00 PM	1 H 0 M	Substation Maintenance
5/21/2026 3:30:02 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BIKHAPUR	chharganji feeder	BENI GADDOPUR	33/11 KV TARUN	Breakdown Shutdown	9453007339	05/21/26 3:05:00 PM	2 H 0 M	11KV Line Fault
5/21/2026 3:30:02 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDDS-BIKHAPUR	rampur feeder	RAMPUR	33/11 KV TARUN	Planned Shutdown	9453007339	05/21/26 3:15:00 PM	0 H 30 M	DT Maintenance
5/21/2026 3:27:12 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-III AYODHYA MILKUPUR	EDDS-IV MILKUPUR	Mote gani	Motiganj	HARINGTANGANI	Breakdown Shutdown	9453007341	05/21/26 3:25:00 PM	1 H 0 M	11KV Line Fault
5/21/2026 3:27:12 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-III AYODHYA MILKUPUR	EDDS-IV MILKUPUR	Harringtongani	HARRINGTANGANI	HARRINGTANGANI	Breakdown Shutdown	9453007341	05/21/26 3:25:00 PM	0 H 25 M	LT/ABC Line Fault
5/21/2026 3:27:12 PM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-III AYODHYA MILKUPUR	EDDS-IV MILKUPUR	Harringtongani	KOCHIHA	HARRINGTANGANI	Breakdown Shutdown	9453007341	05/21/26 3:25:00 PM	0 H 25 M	LT/ABC Line Fault
5/21/2026 3:26:50 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		RAILWAY STATION FEEDER	MUSAFIRKHANA THASEL	Scheduled Rostering	7318095316	05/21/26 6:00:00 AM	1 H 0 M	Rostering
5/21/2026 3:24:23 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		RAILWAY STATION FEEDER	MUSAFIRKHANA THASEL	Emergency Rostering	7318095316	05/21/26 12:30:00 AM	1 H 0 M	Overloading
5/21/2026 3:22:30 PM	MWNL	LUCKNOW	JANKUPURAM	Amethi	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	ENGG COLLEGE	Saraswati Puram janki vihar 60ft road	GALL M Rd Feeder	Planned Shutdown	8004921261	05/21/26 3:20:00 PM	0 H 30 M	Line maintenance
5/21/2026 3:21:20 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		GAURIGANJ CHAURAHA	MUSAFIRKHANA IPS	Scheduled Rostering	7318095316	05/21/26 3:15:00 PM	1 H 0 M	Rostering
5/21/2026 3:21:20 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		GALLAMANDI	MUSAFIRKHANA IPS	Scheduled Rostering	7318095316	05/21/26 6:00:00 AM	1 H 0 M	Rostering
5/21/2026 3:21:05 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-1 BAREILLY	EDDS-II NAWABGANJ	11 kv samuha	SAMUHA	33/11 KV Chunna	Planned Shutdown	9415901668	05/21/26 3:19:00 PM	0 H 20 M	Line maintenance
5/21/2026 3:21:05 PM	MWNL	BAREILLY	BAREILLY-1	EDC-BAREILLY	EDD-1 BAREILLY	EDDS-II NAWABGANJ	11 kv samuha	AHAMADABAD	33/11 KV Chunna	Planned Shutdown	9415901668	05/21/26 3:21:00 PM	0 H 20 M	Line maintenance
5/21/2026 3:20:19 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-CHHATOH		Pandipur	CHHATOH	Scheduled Rostering	9453003030	05/21/26 2:15:00 PM	3 H 0 M	Rostering
5/21/2026 3:20:19 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-CHHATOH		CHHATOH	CHHATOH	Scheduled Rostering	9453003030	05/21/26 2:15:00 PM	3 H 0 M	Rostering
5/21/2026 3:20:19 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-CHHATOH		Nasirabad Town	CHHATOH	Scheduled Rostering	9453003030	05/21/26 2:15:00 PM	3 H 0 M	Rostering
5/21/2026 3:20:19 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-CHHATOH		Chhatoh	CHHATOH	Scheduled Rostering	9453003030	05/21/26 2:15:00 PM	3 H 0 M	Rostering
5/21/2026 3:20:19 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-CHHATOH		Nasirabad Dehat	CHHATOH	Scheduled Rostering	9453003030	05/21/26 2:15:00 PM	3 H 0 M	Rostering
5/21/2026 3:18:26 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		GAURIGANJ CHAURAHA	33/11 KV AMETHI	Planned Shutdown	7318095316	05/21/26 3:14:00 PM	0 H 30 M	Line maintenance
5/21/2026 3:15:25 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		GAURIGANJ CHAURAHA	MUSAFIRKHANA IPS	Emergency Rostering	7318095316	05/21/26 12:30:00 AM	1 H 0 M	Overloading
5/21/2026 3:15:25 PM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		GALLAMANDI	MUSAFIRKHANA IPS	Emergency Rostering	7318095316	05/21/26 12:30:00 AM	1 H 0 M	Overloading
5/21/2026 3:10:18 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDDS-ANJHI		Kaimi	33/11 KV S/5 Chaitya	Planned Shutdown	8004990430	05/21/26 2:45:00 PM	0 H 15 M	Substation Maintenance
5/21/2026 3:10:18 PM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDDS-ANJHI		Dharmapur	33/11 KV S/5 Chaitya	Planned Shutdown	8004990430	05/21/26 2:45:00 PM	0 H 15 M	Substation Maintenance
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:59:32 PM	MWNL	GONDA	DEVIPATAN	EDC-GONDA	EDD-1 GONDA	EDDS-I GONDA	लेख सिफरिंग किया जा रहा 11 के वी की वीर एटान 4 थंया नीला नदी का परस्पर चार	SCPM	220/11 kv Jaii road Gonda	Planned Shutdown	9453007348	05/21/26 3:45:00 PM	2 H 30 M	Shutdown for External Agency Infrastructure Works
5/21/2026 2:54:15 PM	MWNL	RAE BAREILY	RAEBAREILY	EDC-2 RAEBAREILY	EDD-SALON	EDDS-SALON	गोरग							

BDSD REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 11:21:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-II BARABANKI	EDSD-II BARABANKI	teer gaon feeder area only	FEEDER INCOMING NO. 1	33/11 KV BADEL	Breakdown Shutdown	8004922308	05/21/26 3:20:00 PM	0 H 30 M	11KV Line Fault
5/21/2026 11:21:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-II BARABANKI	EDSD-II BARABANKI	all substitution areas		33/11 KV BADEL	Planned Shutdown	8004922308	05/21/26 11:30:00 AM	2 H 30 M	System Improvement Work/Deposit Works
5/21/2026 11:21:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-II BARABANKI	EDSD-II BARABANKI	all substitution areas		33/11 KV BADEL	Planned Shutdown	8004922308	05/21/26 11:30:00 AM	2 H 30 M	System Improvement Work/Deposit Works
5/21/2026 11:21:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-II BARABANKI	EDSD-II BARABANKI	all substitution areas		33/11 KV BADEL	Planned Shutdown	8004922308	05/21/26 11:30:00 AM	2 H 30 M	System Improvement Work/Deposit Works
5/21/2026 11:21:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-II BARABANKI	EDSD-II BARABANKI	all substitution areas		33/11 KV BADEL	Planned Shutdown	8004922308	05/21/26 11:30:00 AM	2 H 30 M	System Improvement Work/Deposit Works
5/21/2026 11:21:44 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR	all substitution areas	Kandwara	Unchahar Rural (Mustafabad)	Breakdown Shutdown	9453005033	05/21/26 11:20:00 AM	4 H 0 M	11KV Line Fault
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Laxmiganj	Unchahar Rural (Mustafabad)	Breakdown Shutdown	9453005033	05/21/26 11:20:00 AM	4 H 0 M	11KV Line Fault
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Arkh	Unchahar Rural (Mustafabad)	Breakdown Shutdown	9453005033	05/21/26 11:20:00 AM	4 H 0 M	11KV Line Fault
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Bhilmapur	Unchahar Rural (Mustafabad)	Breakdown Shutdown	9453005033	05/21/26 11:20:00 AM	4 H 0 M	11KV Line Fault
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Kandwara	Unchahar Rural (Mustafabad)	Scheduled Rostering	9453005033	05/21/26 11:21:00 PM	2 H 0 M	Rostering
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Laxmiganj	Unchahar Rural (Mustafabad)	Scheduled Rostering	9453005033	05/21/26 11:21:00 PM	2 H 0 M	Rostering
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Arkh	Unchahar Rural (Mustafabad)	Scheduled Rostering	9453005033	05/21/26 11:21:00 PM	2 H 0 M	Rostering
5/21/2026 11:21:34 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-UNCHAHAR	EDSD-UNCHAHAR		Bhilmapur	Unchahar Rural (Mustafabad)	Scheduled Rostering	9453005033	05/21/26 11:21:00 PM	2 H 0 M	Rostering
5/21/2026 11:12:37 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-3 LALGANI	EDSD-LALGANI	KANDALIYA Sufiya para Ram nagar	BARASH	UNCHAHAR RURAL	Planned Shutdown	9415099179	05/21/26 11:30:00 AM	0 H 30 M	11KV Line Fault
5/21/2026 11:12:37 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-3 LALGANI	EDSD-LALGANI	BARAs kundwal Narpattganj	Kundwal	UNCHAHAR RURAL	Emergency Rostering	9415099179	05/22/26 12:25:00 AM	2 H 0 M	Transmission Rostering
5/21/2026 11:12:37 AM	MVNL	RAE BARELI	RAEBARELI	EDC-2 RAEARELE	EDD-3 LALGANI	EDSD-LALGANI	BARAs kundwal Narpattganj	Narpattganj	UNCHAHAR RURAL	Emergency Rostering	9415099179	05/22/26 12:25:00 AM	2 H 0 M	Transmission Rostering
5/21/2026 11:05:06 AM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-2 SULTANPUR	EDSD-II KURWAR		Dhannour	Dhannour	Scheduled Rostering	9151997185	05/21/26 11:00:00 AM	2 H 0 M	Rostering
5/21/2026 11:05:06 AM	MVNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-2 SULTANPUR	EDSD-II KURWAR		BANKS	Dhannour	Scheduled Rostering	9151997185	05/21/26 11:00:00 AM	2 H 0 M	Rostering
5/21/2026 11:03:23 AM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-2 BADAUN	EDSD-3 BINAWAR	मौजेनेर बंके के कारण कीडर से सम्बन्धित क्षेत्र की उपस्थिति बद की गयी है	Aurangabad	33/11 KV Binawar	Planned Shutdown	7255104226	05/21/26 10:30:00 AM	1 H 0 M	Line maintenance
5/21/2026 11:03:23 AM	MVNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-2 BADAUN	EDSD-3 BINAWAR	मौजेनेर बंके के कारण कीडर से सम्बन्धित क्षेत्र की उपस्थिति बद की गयी है	Binawar	33/11 KV Binawar	Planned Shutdown	7255104226	05/21/26 10:30:00 AM	1 H 0 M	Line maintenance
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-2	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-2	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-1	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-5	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-3	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:58 AM	MVNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-MEHMUDABAD	EDSD-MEHMUDABAD	महमदुदद रेलवेचर चार हदस	रट्टर-4	33/11 KV MAHMUDABAD THASEEL	Scheduled Rostering	8004918374	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:49:40 AM	MVNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-II IKAUNA		Shrawasti	33/11 KV MOHNA	Breakdown Shutdown	9453004492	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:03 AM	MVNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-II IKAUNA		VEERPUR	Stidwar	Breakdown Shutdown	9453004492	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:03 AM	MVNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-II IKAUNA		katara	Stidwar	Breakdown Shutdown	9453004492	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:59:03 AM	MVNL	SHRAWASTI	DEVPATAN	EDC-BALRAMPUR	EDD-SRAVASTI	EDSD-II IKAUNA		Shivdaha	Stidwar	Breakdown Shutdown	9453004492	05/21/26 9:50:00 PM	1 H 0 M	Rostering
5/21/2026 10:58:45 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-1 RAEARELE (GORA BAZ)		Jawahar Vihar	33/11 KV S/5 ITI	Planned Shutdown	9453005009	05/21/26 11:00:00 AM	1 H 0 M	DT Maintenance
5/21/2026 10:58:45 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-1 RAEARELE (GORA BAZ)		Jawahar Vihar	33/11 KV S/5 ITI	Planned Shutdown	9453005009	05/21/26 11:00:00 AM	1 H 0 M	DT Maintenance
5/21/2026 10:54:44 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-1 RAEARELE (GORA BAZ)		SUBSTATION	33/11 KV S/5 ITI	Breakdown Shutdown	9453005009	05/21/26 12:54:00 PM	1 H 0 M	LT/ABC Line Fault
5/21/2026 10:54:34 AM	MVNL	LUCKNOW	GOMTI NAGAR	EDC-GOMTINAGAR	EDD-GOMTINAGAR	EDSD-GOMTINAGAR	vishramkh 3 44d buddheswar vale transformer ka do kholo gay hai maintenance hetu I	Huseydi FEEDER	GWARI KALVERT	Planned Shutdown	8004921571	05/21/26 10:38:00 AM	2 H 0 M	Line maintenance
5/21/2026 10:48:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSENH GHAT	EDSD-ZAIDPUR	mohta	Arhimabad	33/11 KV MOHNA	Scheduled Rostering	9454464313	05/21/26 10:30:00 AM	3 H 0 M	Rostering
5/21/2026 10:48:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSENH GHAT	EDSD-ZAIDPUR	mohta	Arhimabad	33/11 KV MOHNA	Scheduled Rostering	9454464313	05/21/26 10:30:00 AM	3 H 0 M	Rostering
5/21/2026 10:48:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSENH GHAT	EDSD-ZAIDPUR	mohta	Jarnapur	33/11 KV MOHNA	Scheduled Rostering	9454464313	05/21/26 10:30:00 AM	3 H 0 M	Rostering
5/21/2026 10:46:17 AM	MVNL	BAREILLY	EDC-BAREILLY	EDD-BAREILLY	EDD-BAREILLY	EDSD-I AONLIA		Deochara Har Rampur	33/11 KV BALIA	Breakdown Shutdown	8004949024	05/21/26 10:45:00 AM	8 H 59 M	11KV Line Fault
5/21/2026 10:46:17 AM	MVNL	BAREILLY	EDC-BAREILLY	EDD-BAREILLY	EDD-BAREILLY	EDSD-I AONLIA		CHANDUA	33/11 KV BALIA	Breakdown Shutdown	8004949024	05/21/26 10:45:00 AM	8 H 59 M	11KV Line Fault
5/21/2026 10:46:17 AM	MVNL	BAREILLY	EDC-BAREILLY	EDD-BAREILLY	EDD-BAREILLY	EDSD-I AONLIA		Nawrangpur	33/11 KV BALIA	Emergency Rostering	8004949024	05/21/26 9:50:00 PM	2 H 59 M	Transmission Rostering
5/21/2026 10:46:17 AM	MVNL	BAREILLY	EDC-BAREILLY	EDD-BAREILLY	EDD-BAREILLY	EDSD-I AONLIA		Deochara Har Rampur	33/11 KV BALIA	Emergency Rostering	8004949024	05/21/26 9:50:00 PM	2 H 59 M	Transmission Rostering
5/21/2026 10:46:17 AM	MVNL	BAREILLY	EDC-BAREILLY	EDD-BAREILLY	EDD-BAREILLY	EDSD-I AONLIA		CHANDUA	33/11 KV BALIA	Emergency Rostering	8004949024	05/21/26 9:50:00 PM	2 H 59 M	Transmission Rostering
5/21/2026 10:46:03 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSENH GHAT	EDSD-TIKAIT NAGAR		Harari feeder	33/11 KV KOTWA DHAM	Scheduled Rostering	9807143533	05/21/26 10:35:00 AM	3 H 0 M	Rostering
5/21/2026 10:46:03 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSENH GHAT	EDSD-TIKAIT NAGAR		Saruni Feeder	33/11 KV KOTWA DHAM	Scheduled Rostering	9807143533	05/21/26 10:35:00 AM	3 H 0 M	Rostering
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	NEW MAVAL		33/11 KV P B MAWAI	Planned Shutdown	9453262037	05/21/26 10:40:00 AM	3 H 0 M	Line maintenance
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	RANIMAW		33/11 KV P B MAWAI	Planned Shutdown	9453262037	05/21/26 10:40:00 AM	3 H 0 M	Line maintenance
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	Rajpur		33/11 KV P B MAWAI	Planned Shutdown	9453262037	05/21/26 10:40:00 AM	3 H 0 M	Line maintenance
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	NEWRA		33/11 KV P B MAWAI	Breakdown Shutdown	9453262037	05/21/26 4:05:00 PM	0 H 20 M	LT/ABC Line Fault
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	RANIMAW		33/11 KV P B MAWAI	Breakdown Shutdown	9453262037	05/21/26 4:05:00 PM	0 H 20 M	LT/ABC Line Fault
5/21/2026 10:46:40 AM	MVNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSD-PATRANGA	Rajpur		33/11 KV P B MAWAI	Breakdown Shutdown	9453262037	05/21/26 4:05:00 PM	0 H 20 M	LT/ABC Line Fault
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	DADRA	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 3:42:00 AM	1 H 0 M	Rostering
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	PINDARA	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 3:42:00 AM	1 H 0 M	Rostering
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	KANJIAAZ	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 12:00:00 AM	1 H 55 M	Rostering
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	Substation	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 12:00:00 AM	1 H 55 M	Rostering
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	DADRA	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 12:00:00 AM	1 H 55 M	Rostering
5/21/2026 10:43:11 AM	MVNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDSD-II MUSAFIRKHANA	Musafirkhana power house	PINDARA	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 12:00:00 AM	1 H 55 M	Rostering
5/21/2026 10:41:56 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-I MADHYAN RAEARELE	Musafirkhana power house	KANJIAAZ	MUSAFIRKHANA GRAMIN	Scheduled Rostering	7318095314	05/21/26 12:00:00 AM	1 H 55 M	Rostering
5/21/2026 10:41:56 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-I MADHYAN RAEARELE	SATYANAGAR NIRALANAGAR	pragati puram town	Pragati Puram	Planned Shutdown	9453005001	05/21/26 10:40:00 AM	0 H 10 M	Line maintenance
5/21/2026 10:41:56 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE	EDSD-I MADHYAN RAEARELE	SATYANAGAR NIRALANAGAR	11KV TOWN 1 FEEDER	Pragati Puram	Planned Shutdown	9453005001	05/21/26 10:40:00 AM	0 H 10 M	Line maintenance
5/21/2026 10:41:56 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEARELE	EDD-1 RAEARELE</									

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 9:55:30 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-IV MILKIPUR	gokula	BALDIER	MILKIPUR Rural	Breakdown Shutdown	9453007343	05/21/26 9:54:00 AM	0 H 30 M	11KV Line Fault
5/21/2026 9:55:30 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-IV MILKIPUR	gokula	KHANDASA	MILKIPUR Rural	Breakdown Shutdown	9453007340	05/21/26 9:54:00 AM	0 H 30 M	11KV Line Fault
5/21/2026 9:55:30 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-IV MILKIPUR	gokula	SHAHGANJ	MILKIPUR Rural	Planned Shutdown	9453007342	05/21/26 9:53:00 AM	0 H 10 M	Line maintenance
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	HARDI	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	MAWAI	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	KARDHANA	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	LAUSI	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	HILAUU	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	SHR STATION	33/11 KV HILAUU	Scheduled Rostering	9453005040	05/21/26 12:00:00 AM	0 H 40 M	Rostering
5/21/2026 9:52:24 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	समरपुर	HALIAU	33/11 KV HILAUU	Breakdown Shutdown	9453005040	05/21/26 7:29:00 AM	0 H 5 M	17/ABC Line Fault
5/21/2026 9:47:48 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-RANI BAZAR	सोहनवा	SOHAWA	RANIBAZAR	Breakdown Shutdown	9453007336	05/21/26 9:45:00 AM	1 H 10 M	11KV Line Fault
5/21/2026 9:46:53 AM	MWNL	LUCKNOW	GOMTI NAGAR	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	कांटा	EDC-CHINHAT	Madhya Green	Breakdown Shutdown	9305494572	05/21/26 9:40:00 AM	2 H 30 M	11KV Line Fault
5/21/2026 9:45:36 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALAPUR	EDSD-NEWADA (JALAPUR)	फेडर बेकांगर होने के कारण क्षेत्र की आपूर्ति बाधित है।	Semra	33/11 KV RAFIGANJ	Scheduled Rostering	9453005220	05/21/26 9:44:00 AM	3 H 0 M	Rostering
5/21/2026 9:45:36 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALAPUR	EDSD-NEWADA (JALAPUR)	फेडर बेकांगर होने के कारण क्षेत्र की आपूर्ति बाधित है।	Rafiganj	33/11 KV RAFIGANJ	Scheduled Rostering	9453005220	05/21/26 9:44:00 AM	3 H 0 M	Rostering
5/21/2026 9:45:36 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARPUR)	EDD-JALAPUR	EDSD-NEWADA (JALAPUR)	फेडर बेकांगर होने के कारण क्षेत्र की आपूर्ति बाधित है।	marhara	33/11 KV RAFIGANJ	Scheduled Rostering	9453005220	05/21/26 9:44:00 AM	3 H 0 M	Rostering
5/21/2026 9:42:37 AM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	हाथे वर रोड	DHAKN	33/11 KV S/S PALIA TASEEL	Breakdown Shutdown	9453005091	05/21/26 9:37:00 AM	0 H 40 M	17/ABC Line Fault
5/21/2026 9:42:37 AM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-PALIA	सूरतम सर रोड	babason	33/11 KV S/S PALIA TASEEL	Breakdown Shutdown	9453005091	05/21/26 10:15:00 AM	0 H 25 M	17/ABC Line Fault
5/21/2026 9:41:07 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-RANI BAZAR	अंतपुर	Antpur	RANIBAZAR	Breakdown Shutdown	9453007336	05/21/26 9:00:00 AM	0 H 40 M	11KV Line Fault
5/21/2026 9:41:07 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-RANI BAZAR	अंतपुर	Antpur	SOHAWA	Breakdown Shutdown	9453007336	05/21/26 9:00:00 AM	0 H 40 M	11KV Line Fault
5/21/2026 9:34:39 AM	MWNL	BAREILLY-1	EDC-BAREILLY	EDD-1 BAREILLY	EDSD-1 MEERGANJ	EDSD-1 MEERGANJ	तांश	TAHSHI	33/11 KV MEERGANJ TASEEL	Emergency Rostering	9453005124	05/21/26 12:01:00 AM	2 H 5 M	Transmission Rostering
5/21/2026 9:34:39 AM	MWNL	BAREILLY-1	EDC-BAREILLY	EDD-1 BAREILLY	EDSD-1 MEERGANJ	EDSD-1 MEERGANJ	तांश	Station	33/11 KV MEERGANJ TASEEL	Emergency Rostering	9453005124	05/21/26 12:01:00 AM	2 H 5 M	Transmission Rostering
5/21/2026 9:33:42 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-1 AYODHYA	AYODHYA	11 क्वी ललाट फेडर होने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	RAM KI PAIDI	Breakdown Shutdown	9453005201	05/21/26 7:30:00 AM	2 H 30 M	11KV Line Fault	
5/21/2026 9:30:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	EDSD-BIKHAPUR	S.W	33/11 KV BIKHAPUR RURAL	Breakdown Shutdown	9453007337	05/21/26 9:29:00 AM	0 H 10 M	17/ABC Line Fault
5/21/2026 9:29:15 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-KUMARGANJ	EDSD-KUMARGANJ	33/11 Tulsipur	33/11 Tulsipur	Breakdown Shutdown	9453007342	05/21/26 9:29:00 AM	1 H 10 M	17/ABC Line Fault
5/21/2026 9:29:15 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD III AYODHYA MILKPUR	EDSD-KUMARGANJ	EDSD-KUMARGANJ	Degatop	33/11 Shikhar Pur	Breakdown Shutdown	9453007342	05/21/26 9:29:00 AM	0 H 20 M	17/ABC Line Fault
5/21/2026 9:26:56 AM	MWNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-NADARGANJ	EDSD-GEHRU	राजद अड्डा बिकर फाट हो जाने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	ROGOA KHERA	33/11 KV S/S Gahru	Breakdown Shutdown	8004921272	05/21/26 4:30:00 AM	14 H 30 M	11KV Line Fault
5/21/2026 9:24:49 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-GOSHAINGANJ	JAMUNPUR	Tandauli	Breakdown Shutdown	9453012037	05/21/26 8:55:00 AM	0 H 35 M	11KV Line Fault	
5/21/2026 9:24:49 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-GOSHAINGANJ	JAMUNPUR	Tandauli	Breakdown Shutdown	9453012037	05/21/26 8:55:00 AM	0 H 35 M	11KV Line Fault	
5/21/2026 9:24:49 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-GOSHAINGANJ	JAMUNPUR	Tandauli	Breakdown Shutdown	9453012037	05/21/26 8:55:00 AM	0 H 35 M	11KV Line Fault	
5/21/2026 9:18:57 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	TAKATORA	EDD-2 AYODHYA	EDSD-RAJAPURAM	राजद अड्डा बिकर फाट हो जाने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	ROSO	EDD-2 AYODHYA	Breakdown Shutdown	8004921249	05/21/26 7:00:00 AM	4 H 0 M	11KV Line Fault
5/21/2026 9:18:57 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-GOSHAINGANJ	फेडर बेकांगर होने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	DEORGA	BAKARGANJ (MAYA BAZAR)	Breakdown Shutdown	9453007334	05/21/26 5:40:00 AM	2 H 0 M	11KV Line Fault
5/21/2026 9:14:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDSD-III BARABANKI	vishnupur related total area	VISHNU PUR	33/11 KV DEVA	Scheduled Rostering	9453005252	05/21/26 8:30:00 AM	3 H 0 M	Rostering
5/21/2026 9:08:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDSD-ZAIDPUR	रंजरी रोड अंतपुरी	Udhuloi	33/11 KV SARDARGANJ	Emergency Rostering	9453005258	05/21/26 9:00:00 AM	2 H 30 M	Overloading
5/21/2026 9:08:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDSD-ZAIDPUR	रंजरी रोड अंतपुरी	Purana Palahri	33/11 KV SARDARGANJ	Scheduled Rostering	9453005258	05/21/26 9:00:00 AM	2 H 30 M	Overloading
5/21/2026 9:08:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDD-RAMSENEH GHAT	रंजरी बागीचा फेडर	Safarganj	33/11 KV SARDARGANJ	Emergency Rostering	9453005258	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:08:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDD-RAMSENEH GHAT	रंजरी बागीचा फेडर	Udhuloi	33/11 KV SARDARGANJ	Emergency Rostering	9453005258	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:08:17 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDD-RAMSENEH GHAT	रंजरी बागीचा फेडर	Pratalaj	33/11 KV SARDARGANJ	Emergency Rostering	9453005258	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:07:14 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDSD-ZAIDPUR	रंजरी बागीचा फेडर	BRAGALI	33/11 KV SARDARGANJ	Emergency Rostering	9453005258	05/21/26 11:00:00 PM	2 H 0 M	Transmission Rostering
5/21/2026 9:07:14 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	11kv Birauli feeder 250kva bhadobhar	BRAGALI	33/11 KV SARDARGANJ	Breakdown Shutdown	9453007335	05/21/26 1:09:00 PM	0 H 15 M	DT Damaged/DT Fuse Burnt/Fire on DT
5/21/2026 9:07:14 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BAKARGANJ	11kv Bharatnand feeder	BHARATKUND	MASHOHA	Breakdown Shutdown	9453007335	05/21/26 6:50:00 AM	1 H 45 M	17/ABC Line Fault
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	Khitaura	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 12:40:00 AM	0 H 40 M	Rostering
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	Bilapaur	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 12:40:00 AM	0 H 40 M	Rostering
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	BAREILLY	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 12:40:00 AM	0 H 30 M	Rostering
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	Pindool	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 5:00:00 AM	0 H 30 M	Rostering
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	Khitaura	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 5:00:00 AM	0 H 30 M	Rostering
5/21/2026 9:05:26 AM	MWNL	BUDAUN	BAREILLY-2	EDC-BADAUN	EDD-3 BISAUJI	EDSD-I ISLAMNAGAR	Khitaura	Bilapaur	33/11 KV KHITORA	Scheduled Rostering	9761987299	05/21/26 5:00:00 AM	0 H 30 M	Rostering
5/21/2026 9:05:15 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDSD-KOYAL BAG	खिताुरा	Police LINE	33/11 KV S/S KOYAL BAGH	Planned Shutdown	9453005106	05/21/26 9:00:00 AM	1 H 0 M	Line maintenance
5/21/2026 9:05:15 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDSD-KOYAL BAG	खिताुरा	Police LINE	33/11 KV S/S KOYAL BAGH	Planned Shutdown	9453005106	05/21/26 9:00:00 AM	1 H 0 M	Line maintenance
5/21/2026 9:04:43 AM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-2 SULTANPUR	EDSD-KURWAR	रामपुर फेडर	KUDHIMAN	Dhannour	Scheduled Rostering	9151997185	05/21/26 9:00:00 AM	2 H 0 M	Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	rampur feeder	RAMPUR	33/11 KV TARUN	Breakdown Shutdown	9453007339	05/21/26 8:45:00 AM	0 H 45 M	DT Damaged/DT Fuse Burnt/Fire on DT
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	RAMPUR	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	EDSD-BIKHAPUR	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	DHURAIRA	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	GHURU THAKA	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	BENI GADDDOPUR	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 9:02:11 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSD-BIKHAPUR	tarun and Gysphur substation	Bagra Feeder	33/11 KV TARUN	Emergency Rostering	9453007339	05/21/26 3:15:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 8:57:50 AM	MWNL	Lakhimpur KHERI	SITAPUR	EDC-GOLA	EDD-2 MOHAMMADI	EDSD-1 MOHAMMADI	सुखिया	Sukhiya	33/11 KV SUKHAWSA	Breakdown Shutdown	7607103885	05/21/26 8:57:00 AM	1 H 1 M	11KV Line Fault
5/21/2026 8:50:36 AM	MWNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-DUBAGGA	EDSD-DUBAGGA	ABC ललाट फाट हो जाने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	ABC ललाट फाट हो जाने के कारण फेडर से सम्बंधित कुछ क्षेत्र की आपूर्ति बाधित है।	33/11 KV BASANTUNJ DUBAGGA NEW	Breakdown Shutdown	9451950635	05/21/26 4:00:00 AM	11 H 0 M	17/ABC Line Fault
5/21/2026 8:47:36 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDSD-I BARABANKI	TEER GAON	TEER GAON	33/11 KV BADEL					

BDSD REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 7:55:31 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-TILOI	EDD-TILOI	INHAUNA	Semrauta	Emergency Rostering	945300503	05/21/26 1:57:00 AM	0 H 50 M	Transmission Rostering	
5/21/2026 7:55:31 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-TILOI	EDD-TILOI	Mehnar	Semrauta	Emergency Rostering	945300503	05/21/26 1:57:00 AM	0 H 50 M	Transmission Rostering	
5/21/2026 7:55:31 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-TILOI	EDD-TILOI	Semrauta	Semrauta	Emergency Rostering	945300503	05/21/26 1:57:00 AM	0 H 50 M	Transmission Rostering	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	RASULABAD	RASULABAD	Scheduled Rostering	9453007332	05/21/26 7:53:00 AM	0 H 45 M	Rostering	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	KUMBHYA	RASULABAD	Scheduled Rostering	9453007332	05/21/26 7:53:00 AM	0 H 45 M	Rostering	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	NARAYAN PUR	RASULABAD	Scheduled Rostering	9453007332	05/21/26 7:53:00 AM	0 H 45 M	Rostering	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	RASULABAD	RASULABAD	Breakdown Shutdown	9453007332	05/21/26 4:25:00 PM	0 H 15 M	17/ABC Line Fault	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	RASULABAD	RASULABAD	Breakdown Shutdown	9453007332	05/21/26 4:25:00 PM	0 H 15 M	17/ABC Line Fault	
5/21/2026 7:53:52 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BAKARGANI	RASULABAD	RASULABAD	Breakdown Shutdown	9453007332	05/21/26 4:25:00 PM	0 H 15 M	17/ABC Line Fault	
5/21/2026 7:53:46 AM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSS-II BAHRAICH	CHANDAN PUR	BASHIR GANI	Breakdown Shutdown	8004793109	05/21/26 7:53:00 AM	2 H 0 M	11KV Line Fault	
5/21/2026 7:53:46 AM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSS-II BAHRAICH	BASIR GANI	BASHIR GANI	Breakdown Shutdown	8004793109	05/21/26 7:53:00 AM	2 H 0 M	11KV Line Fault	
5/21/2026 7:53:46 AM	MWNL	BAHRAICH	DEVPATAN	EDC-BAHRAICH	EDD-I BAHRAICH	EDSS-II BAHRAICH	NARAYAN PUR	BASHIR GANI	Breakdown Shutdown	8004793109	05/21/26 7:53:00 AM	2 H 0 M	11KV Line Fault	
5/21/2026 7:53:09 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARRPUR)	EDD-ALAPUR	EDSS-BASHARI	SARDAR NAGAR	33/11 DARGAH KICHOCHA	Scheduled Rostering	955408255	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:53:09 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARRPUR)	EDD-ALAPUR	EDSS-BASHARI	Mara	33/11 DARGAH KICHOCHA	Scheduled Rostering	955408255	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:49:22 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-AMETHI	EDSS-Amethi	Amethi	Amethi	Breakdown Shutdown	7318040423	05/21/26 7:47:00 AM	0 H 10 M	17/ABC Line Fault	
5/21/2026 7:44:57 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-CHOWK	EDSS-CHOWK	NADAN MAHAL	ghantaghar power house se sambandhit sabhi area band rahaga gulab Park feeder Nana	Planned Shutdown	8887158601	05/21/26 7:42:00 AM	1 H 10 M	Line maintenance	
5/21/2026 7:44:57 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-CHOWK	EDSS-CHOWK	NADAN MAHAL	ghantaghar power house se sambandhit sabhi area band rahaga gulab Park feeder Nana	Planned Shutdown	8887158601	05/21/26 7:42:00 AM	1 H 10 M	Line maintenance	
5/21/2026 7:44:57 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-CHOWK	EDSS-CHOWK	NADAN MAHAL	ghantaghar power house se sambandhit sabhi area band rahaga gulab Park feeder Nana	Planned Shutdown	8887158601	05/21/26 7:42:00 AM	1 H 10 M	Line maintenance	
5/21/2026 7:44:57 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-CHOWK	EDSS-CHOWK	NADAN MAHAL	ghantaghar power house se sambandhit sabhi area band rahaga gulab Park feeder Nana	Planned Shutdown	8887158601	05/21/26 7:42:00 AM	1 H 10 M	Line maintenance	
5/21/2026 7:44:51 AM	MWNL	BARILLY	BARILLY-1	EDC-BARILLY	EDD-1 BARILLY	EDSS-I NAWABGANI	Barilly	NAWABGANI TENSIL	Breakdown Shutdown	9453005133	05/21/26 7:43:00 AM	0 H 10 M	17/ABC Line Fault	
5/21/2026 7:44:51 AM	MWNL	BARILLY	BARILLY-1	EDC-BARILLY	EDD-1 BARILLY	EDSS-I NAWABGANI	Barilly	NAWABGANI TENSIL	Breakdown Shutdown	9453005133	05/21/26 7:43:00 AM	0 H 10 M	17/ABC Line Fault	
5/21/2026 7:43:33 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-GOSHANGANI	SARAIYA	GOSAIGANI Tahseel	Scheduled Rostering	9453007333	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:43:33 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-GOSHANGANI	TOWN	GOSAIGANI Tahseel	Scheduled Rostering	9453007333	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	CHALIRE	33/11 KV MANGARI	Scheduled Rostering	9453007340	05/21/26 7:40:00 AM	1 H 30 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	CHALIRE	33/11 KV MANGARI	Scheduled Rostering	9453007340	05/21/26 7:40:00 AM	1 H 30 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	BATTI FEEDER	33/11 KV MANGARI	Scheduled Rostering	9453007340	05/21/26 7:40:00 AM	1 H 30 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	KHARUAHAT	33/11 KV MANGARI	Scheduled Rostering	9453007340	05/21/26 7:40:00 AM	1 H 30 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	MANGARI	33/11 KV MANGARI	Scheduled Rostering	9453007340	05/21/26 7:40:00 AM	1 H 30 M	Rostering	
5/21/2026 7:40:54 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-2 AYODHYA	EDSS-BIKHAPUR	MANGARI	33/11 KV MANGARI	Planned Shutdown	9453007340	05/21/26 4:25:00 PM	0 H 10 M	Line maintenance	
5/21/2026 7:40:38 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSS-BHAGWANT NAGAR	UNCHGAON	33/11 KV S/5 BHAGWANT NAGAR	Scheduled Rostering	9453005037	05/21/26 6:00:00 AM	3 H 0 M	Rostering	
5/21/2026 7:40:38 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSS-BHAGWANT NAGAR	MAHESI KHERA	33/11 KV S/5 BHAGWANT NAGAR	Scheduled Rostering	9453005037	05/21/26 6:00:00 AM	3 H 0 M	Rostering	
5/21/2026 7:40:38 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSS-BHAGWANT NAGAR	SUMERPUR	33/11 KV S/5 BHAGWANT NAGAR	Scheduled Rostering	9453005037	05/21/26 6:00:00 AM	3 H 0 M	Rostering	
5/21/2026 7:37:57 AM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-I GONDA	EDSS-I GONDA	JAIS Agtal	Badgaon Gonda	Breakdown Shutdown	8004817714	05/21/26 7:00:00 AM	2 H 30 M	11KV Line Fault	
5/21/2026 7:37:57 AM	MWNL	GONDA	DEVPATAN	EDC-GONDA	EDD-I GONDA	EDSS-I GONDA	JAIS Agtal	Badgaon Gonda	Breakdown Shutdown	8004817714	05/21/26 7:00:00 AM	2 H 30 M	11KV Line Fault	
5/21/2026 7:37:52 AM	MWNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-UJHANI	EDSS-I UJHANI	Chudhya	33/11 KV BURRAFARIDPUR	Scheduled Rostering	7995602524	05/21/26 7:26:00 AM	3 H 12 M	Rostering	
5/21/2026 7:37:52 AM	MWNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-UJHANI	EDSS-I UJHANI	FEEDER NO. 80	33/11 KV BURRAFARIDPUR	Scheduled Rostering	7995602524	05/21/26 7:26:00 AM	3 H 12 M	Rostering	
5/21/2026 7:37:52 AM	MWNL	BUDAUN	BARILLY-2	EDC-BADAUN	EDD-UJHANI	EDSS-I UJHANI	80NO feeder chudhya feeder Burra mandir feeder	33/11 KV BURRAFARIDPUR	Scheduled Rostering	7995602524	05/21/26 7:26:00 AM	3 H 12 M	Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:36:48 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSS-PALIA	all area off feeder by palia rural	patwara	Emergency Rostering	9453005093	05/21/26 12:00:00 AM	0 H 40 M	Transmission Rostering	
5/21/2026 7:34:34 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDSS-BANTHAR	banthar feeder me shalendra Im ko dya shutdown dya shukapur me ta 1 ta 2 noedne	33/11 KV BANTHER RURAL	Breakdown Shutdown	8015092302	05/21/26 7:05:00 AM	1 H 0 M	17/ABC Line Fault	
5/21/2026 7:34:34 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDSS-BANTHAR	banthar feeder me shalendra Im ko dya shutdown dya shukapur me ta 1 ta 2 noedne	33/11 KV BANTHER 2	Breakdown Shutdown	8015092302	05/21/26 7:05:00 AM	1 H 0 M	17/ABC Line Fault	
5/21/2026 7:24:10 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANI (Amethi)	EDD-AMETHI	EDSS-Amethi	Rebha	33/11 KV KHERAUNA	Emergency Rostering	7318040419	05/21/26 3:34:00 AM	1 H 0 M	Transmission Rostering	
5/21/2026 7:13:49 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDSS-PHANI	Gopamu Town	33/11 KV S/5 Gopamu	Emergency Rostering	8005490439	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:13:49 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDSS-PHANI	Deulgur	33/11 KV S/5 Gopamu	Scheduled Rostering	8005490439	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:13:49 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDSS-PHANI	Tendaur	33/11 KV S/5 Gopamu	Scheduled Rostering	8005490439	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:13:49 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SHAHAD	EDSS-PHANI	132 ss	33/11 KV S/5 Gopamu	Scheduled Rostering	8005490439	05/21/26 6:00:00 AM	1 H 0 M	Rostering	
5/21/2026 7:08:23 AM	MWNL	AMBEDKAR NAGAR	AYODHYA	EDC-AMBEDKAR NAGAR (AKBARRPUR)	EDD-JALALPUR	EDSS-I JALALPUR	Tehil feeder	JALALPUR Tehsil	Scheduled Rostering	800418422	05/21/26 6:05:00 AM	1 H 0 M	Rostering	
5/21/2026 7:06:04 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSS-RUDAUJI	All 11 KV FEDER AREA	Ahlar	Emergency Rostering	9453005265	05/21/26 4:58:00 AM	0 H 45 M	Transmission Rostering	
5/21/2026 7:06:04 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSS-RUDAUJI	ALL 11 KV FEDER AREA	Ahlar	Emergency Rostering	9453005265	05/21/26 4:58:00 AM	0 H 45 M	Transmission Rostering	
5/21/2026 7:06:04 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAUJI	EDSS-RUDAUJI	DUE TO VIL AHAR TF FUSE REPLACE	Ahlar	Breakdown Shutdown	9453005265	05/21/26 9:35:00 AM	0 H 5 M	17/ABC Line Fault	
5/21/2026 7:04:51 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDSS-KOYAL BAG	all feeder	INDUSTRIAL	Breakdown Shutdown	800478422	05/21/26 6:50:00 AM	1 H 30 M	33KV Line Fault	
5/21/2026 7:04:51 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDSS-KOYAL BAG	all feeder	Sub Station	Breakdown Shutdown	800478422	05/21/26 6:50:00 AM	1 H 30 M	33KV Line Fault	
5/21/2026 7:04:51 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDSS-KOYAL BAG	all feeder	ROTO (Hardoi)	Breakdown Shutdown	800478422	05/21/26 6:50:00 AM	1 H 30 M	33KV Line Fault	
5/21/2026 7:03:07 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDSS-TULSIPUR	CHINI MILL	33/11 KV IPSD TULSIPUR	Scheduled Rostering	8090778533	05/21/26 6:30:00 AM	1 H 30 M	Rostering	
5/21/2026 7:03:07 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDSS-TULSIPUR	HANUMAN GARHI	33/11 KV IPSD TULSIPUR	Scheduled Rostering	8090778533	05/21/26 6:30:00 AM	1 H 30 M	Rostering	
5/21/2026 7:01:45 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDSS-Barbar	Bargadya	33/11 KV S/5 Barbar Rural	Breakdown Shutdown	9670701861	05/21/26 9:05:00 PM	0 H 30 M	11KV Line Fault	
5/21/2026 7:01:45 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDSS-Barbar	Enapur	33/11 KV S/5 Barbar Rural	Breakdown Shutdown	9670701861	05/21/26 9:05:00 PM	0 H 30 M	11KV Line Fault	
5/21/2026 7:01:45 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDSS-Barbar	Barbar	33/11 KV S/5 Barbar Rural	Breakdown Shutdown	9670701861	05/21/26 9:05:00 PM	0 H 30 M	11KV Line Fault	
5/21/2026 7:01:45 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDSS-Barbar	link line	33/11 KV S/5 Barbar Rural	Breakdown Shutdown	9670701861	0			

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Pashaur	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		BASUPUR	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Patihara 2	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		BASUPUR-2	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Jamunabad	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:55:12 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Amritapur	33/11 KV S/5 ALGANJ	Scheduled Rostering	7376446359	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:54:28 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Shikharan	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	936905562	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:54:28 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Bhupur	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	936905562	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:54:28 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Shivpur	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	936905562	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:54:28 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-GOLA	EDDS-II GOLA		Substation	33/11 KV S/5 MUDA SAWARAN	Scheduled Rostering	936905562	05/21/26 5:45:00 AM	0 H 45 M	Rostering
5/21/2026 6:51:22 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDDS-REHRA		achalpur chudhary	33/11 KV ACHALPUR CHAUDHARY	Emergency Rostering	9415901532	05/21/26 1:50:00 AM	2 H 30 M	Transmission Rostering
5/21/2026 6:51:22 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDDS-REHRA		COLONEY	33/11 KV ACHALPUR CHAUDHARY	Emergency Rostering	9415901532	05/21/26 6:05:00 AM	0 H 15 M	Transmission Rostering
5/21/2026 6:51:22 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDDS-REHRA		achalpur chudhary	33/11 KV ACHALPUR CHAUDHARY	Emergency Rostering	9415901532	05/21/26 6:05:00 AM	0 H 15 M	Transmission Rostering
5/21/2026 6:51:22 AM	MWNL	BALRAMPUR	DEVPATAN	EDC-BALRAMPUR	EDD-TULSIPUR	EDDS-REHRA		achalpur chudhary	33/11 KV ACHALPUR CHAUDHARY	Emergency Rostering	9415901532	05/21/26 6:05:00 AM	0 H 15 M	Transmission Rostering
5/21/2026 6:41:50 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDDS-MAIGALGANJ		LINK LINE	33/11 KV SS AJURANGABAD	Emergency Rostering	8318368680	05/21/26 5:00:00 AM	0 H 45 M	Rostering
5/21/2026 6:41:50 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDDS-MAIGALGANJ		ALIRANGABAD	33/11 KV SS AJURANGABAD	Emergency Rostering	8318368680	05/21/26 5:00:00 AM	0 H 45 M	Rostering
5/21/2026 6:41:50 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDDS-MAIGALGANJ		ALIRANGABAD	33/11 KV SS AJURANGABAD	Emergency Rostering	8318368680	05/21/26 5:00:00 AM	0 H 45 M	Rostering
5/21/2026 6:41:50 AM	MWNL	Lakhipur KHERI	SITAPUR	EDC-GOLA	EDD-II MOHAMMADI	EDDS-MAIGALGANJ		WORLD BANK	33/11 KV SS AJURANGABAD	Emergency Rostering	8318368680	05/21/26 5:00:00 AM	0 H 45 M	Rostering
5/21/2026 6:40:55 AM	MWNL	SULTANPUR	AYODHYA	EDC-SULTANPUR	EDD-LAMBHUA	EDDS-III LAMBHUA		Pandey Pur	33/11 KV S/5 ALGANJ	Breakdown Shutdown	8887190023	05/21/26 12:05:00 AM	5 H 35 M	33KV Line Fault
5/21/2026 6:35:31 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAHLI	EDDS-PATRANGA		KATTHI	33/11 KV SUJAGANJ	Emergency Rostering	9129614300	05/21/26 1:45:00 AM	1 H 45 M	Transmission Rostering
5/21/2026 6:35:31 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAHLI	EDDS-PATRANGA		KATTHI	33/11 KV SUJAGANJ	Emergency Rostering	9129614300	05/21/26 1:45:00 AM	1 H 45 M	Transmission Rostering
5/21/2026 6:35:31 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAHLI	EDDS-PATRANGA		KATTHI	33/11 KV SUJAGANJ	Emergency Rostering	9129614300	05/21/26 1:45:00 AM	1 H 45 M	Transmission Rostering
5/21/2026 6:35:31 AM	MWNL	AYODHYA	AYODHYA	EDC-AYODHYA	EDD-RUDAHLI	EDDS-PATRANGA		KATTHI	33/11 KV SUJAGANJ	Emergency Rostering	9129614300	05/21/26 1:45:00 AM	1 H 45 M	Transmission Rostering
5/21/2026 6:35:00 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SANDILA	EDDS-KACHAUNA		Sujanbhai Bazar	33/11 KV S/5 Baghail	Scheduled Rostering	9453005104	05/21/26 5:20:00 AM	2 H 30 M	Rostering
5/21/2026 6:35:00 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-SANDILA	EDDS-KACHAUNA		Bashedha	33/11 KV S/5 Baghail	Scheduled Rostering	9453005104	05/21/26 5:20:00 AM	2 H 30 M	Rostering
5/21/2026 6:32:27 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		AKOHI	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 6:05:00 AM	0 H 50 M	Rostering
5/21/2026 6:32:27 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		ASGARGANJ	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 6:05:00 AM	0 H 50 M	Rostering
5/21/2026 6:32:27 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		RAJASTON	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 6:05:00 AM	0 H 50 M	Rostering
5/21/2026 6:32:27 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		Bhawaniganj	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 6:05:00 AM	0 H 50 M	Rostering
5/21/2026 6:27:42 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDDS-III BARABANKI		GAUSAODIPUR	33/11 BANKI	Scheduled Rostering	9415902678	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 6:27:42 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDDS-III BARABANKI		GAUSAODIPUR	33/11 BANKI	Scheduled Rostering	9415902678	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 6:27:42 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDDS-III BARABANKI		ASHDIPUR	33/11 BANKI	Scheduled Rostering	9415902678	05/21/26 5:30:00 AM	1 H 0 M	Rostering
5/21/2026 6:27:42 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-BARABANKI	EDDS-III BARABANKI		ASHDIPUR	33/11 BANKI	Scheduled Rostering	9415902678	05/21/26 5:30:00 AM	1 H 0 M	Rostering
5/21/2026 6:25:53 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-RESIDENCY	LUPL	Asptali gaj durjiga Ganj Raniganj chouraha	RANIGANJ	33/11 KV UPLRAENDRA NAGAR)	Breakdown Shutdown	8004921219	05/21/26 6:21:00 AM	3 H 0 M	LT/ABC Line Fault
5/21/2026 6:24:12 AM	MWNL	HARDOI	SITAPUR	EDC-HARDOI	EDD-2 HARDOI	EDDS-KOYAL BAG		Town- 1	33/11KV MANNAPURWA	Planned Shutdown	9453005109	05/21/26 6:30:00 AM	1 H 0 M	Shutdown for External Agency Infrastructure Works
5/21/2026 6:19:19 AM	MWNL	AKHILASHAR NAGAR	SITAPUR	EDC-RAJOURI NAGAR (AKBARPUR)	EDD-2 HARDOI	EDDS-KOYAL BAG		Town- 2	33/11KV MANNAPURWA	Planned Shutdown	9453005109	05/21/26 6:30:00 AM	1 H 0 M	Shutdown for External Agency Infrastructure Works
5/21/2026 6:19:19 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDDS-BANTHAR	Rifalganj	AYODHYA	33/11 KV UPRATTIGANJ/EDDS-II Tang	Scheduled Rostering	9415902302	05/21/26 1:25:00 AM	1 H 1 M	Rostering
5/21/2026 6:19:19 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDDS-BANTHAR	scheduled roasting of 33kv banthar 2nd gramin	BDARKA	33/11 KV Banthar 2	Scheduled Rostering	9415902302	05/21/26 6:05:00 AM	0 H 30 M	Rostering
5/21/2026 6:19:19 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDDS-BANTHAR	scheduled roasting of 33kv banthar 2nd gramin	Kariyakheda rural	33/11 KV Banthar 2	Scheduled Rostering	9415902302	05/21/26 6:05:00 AM	0 H 30 M	Rostering
5/21/2026 6:19:19 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-2 UNNAO	EDDS-BANTHAR	scheduled roasting of 33kv banthar 2nd gramin	Korari rural	33/11 KV Banthar 2	Scheduled Rostering	9415902302	05/21/26 6:05:00 AM	0 H 30 M	Rostering
5/21/2026 6:11:02 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMALU	EDDS-II SAFIPUR	33 KV safipur rural roasting from transmission	11 KV PARIVAR	SAFIPUR SUBSTATION	Emergency Rostering	9453007434	05/21/26 1:25:00 AM	1 H 15 M	Transmission Rostering
5/21/2026 6:11:02 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMALU	EDDS-II SAFIPUR	33 KV safipur rural roasting from transmission	11 KV ASIWAN	SAFIPUR SUBSTATION	Emergency Rostering	9453007434	05/21/26 1:25:00 AM	1 H 15 M	Transmission Rostering
5/21/2026 6:11:02 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMALU	EDDS-II SAFIPUR	33 KV safipur rural roasting from transmission	11 KV PARIVAR	SAFIPUR SUBSTATION	Emergency Rostering	9453007434	05/21/26 6:05:00 AM	1 H 10 M	Transmission Rostering
5/21/2026 6:11:02 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-4 BANGARMALU	EDDS-II SAFIPUR	33 KV safipur rural roasting from transmission	11 KV ASIWAN	SAFIPUR SUBSTATION	Emergency Rostering	9453007434	05/21/26 6:05:00 AM	1 H 10 M	Transmission Rostering
5/21/2026 6:10:04 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-DEVIKANJ	A group open 30 minits	SARAYA VISHOYAN	Kariya	Planned Shutdown	8004915172	05/21/26 6:08:00 AM	0 H 30 M	Line maintenance
5/21/2026 6:10:04 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-DEVIKANJ	A group open 30 minits	Palua	SUBEHA	Planned Shutdown	8004915172	05/21/26 6:08:00 AM	0 H 30 M	Line maintenance
5/21/2026 6:10:04 AM	MWNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-HADERGARH	EDDS-DEVIKANJ	A group open 30 minits	Chakura	SUBEHA	Planned Shutdown	8004915172	05/21/26 6:08:00 AM	0 H 30 M	Line maintenance
5/21/2026 6:06:50 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		11KV SUBSTATION FEEDER	MAURAWAN TOWN	Scheduled Rostering	8400710211	05/21/26 6:03:00 AM	1 H 0 M	Rostering
5/21/2026 6:06:50 AM	MWNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDDS-MAURAWN		11KV MAURAWAN TOWN FEEDER	MAURAWAN TOWN	Scheduled Rostering	8400710211	05/21/26 6:03:00 AM	1 H 0 M	Rostering
5/21/2026 6:05:35 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		Rayaband	GAURIGANJ SUBSTATION	Emergency Rostering	7318095317	05/21/26 4:10:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:05:35 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		SARAYA VISHOYAN	Kariya	Emergency Rostering	7318095317	05/21/26 4:10:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:05:35 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		Jamuwari	Kariya	Emergency Rostering	7318095317	05/21/26 4:10:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 6:03:38 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		Rasulabad	Kariya	Emergency Rostering	7318095317	05/21/26 1:55:00 AM	0 H 50 M	Transmission Rostering
5/21/2026 6:03:38 AM	MWNL	Amethi	AYODHYA	EDC-GAURIGANJ (Amethi)	EDD-GAURIGANJ	EDDS-I MUSAFIRKHANA		SARAYA VISHOYAN	Kariya	Emergency Rostering	7318095317	05/21/26 1:55:00 AM	0 H 50 M	Transmission Rostering
5/21/2026 6:03:26 AM	MWNL	LUCKNOW	LUCKNOW CENTRAL	TALKATORA	EDD-RAJAJIPURAM	EDDS-RAJAJIPURAM NEW	उदरखण्ड केबल फॉल्ट होने के कारण पीडर से रजमॉचिण क्षेत्र को अल्पत्ति बाधित है	Mohan Road Feeder	RAJAJIPURAM (NEW)	Breakdown Shutdown	8004912251	05/21/26 4:30:00 AM	5 H 30 M	11KV Line Fault
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-KHAIIRABAD	EDDS-KHAIIRABAD		PANI TANKI	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-SIDHAULI	EDDS-KHAIIRABAD		TURK PATTI	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-SIDHAULI	EDDS-KHAIIRABAD		SITAPUR	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-SIDHAULI	EDDS-KHAIIRABAD		PANI KI TANKI	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-SIDHAULI	EDDS-KHAIIRABAD		TURK PATTI	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM	MWNL	SITAPUR	SITAPUR	EDC-SITAPUR	EDD-SIDHAULI	EDDS-KHAIIRABAD		B C M ROAD	33/11 KV KHAIIRA BAD	Scheduled Rostering	8004918461	05/21/26 6:02:00 AM	1 H 0 M	Rostering
5/21/2026 6:02:50 AM														

BDSO REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 4:13:07 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	JATHITHI	33/11 KV DULAADEPUR	Scheduled Rostering	9415901611	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 4:13:07 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	Katwa Sadak	33/11 KV DULAADEPUR	Scheduled Rostering	9415901611	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 4:13:07 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	Nimta colony	33/11 KV DULAADEPUR	Scheduled Rostering	9415901611	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 4:13:07 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	Nimtayapur	33/11 KV DULAADEPUR	Scheduled Rostering	9415901611	05/21/26 5:30:00 AM	3 H 0 M	Rostering
5/21/2026 4:10:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-TIKAIT NAGAR	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	TIKAIT NAGAR	33/11 KV PURE DALAI	Breakdown Shutdown	9453005261	05/21/26 1:50:00 AM	8 H 10 M	Power Transformer Fault
5/21/2026 4:10:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-TIKAIT NAGAR	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	KHATASARAI FEEDAR	33/11 KV PURE DALAI	Breakdown Shutdown	9453005261	05/21/26 1:50:00 AM	8 H 10 M	Power Transformer Fault
5/21/2026 4:10:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-TIKAIT NAGAR	132 kva टूरसिफिड से फाल्ट होने के कारण आपूर्ति बाधित है।	TIKAVAMU FEEDAR	33/11 KV PURE DALAI	Breakdown Shutdown	9453005261	05/21/26 1:50:00 AM	8 H 10 M	Power Transformer Fault
5/21/2026 4:10:44 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-TIKAIT NAGAR	सोमपुर परबारी पैस करतें बच्चे हैं	TIKAVAMU FEEDAR	33/11 KV PURE DALAI	Breakdown Shutdown	9453005261	05/21/26 12:55:00 PM	0 H 10 M	LT/ABC Line Fault
5/21/2026 4:09:41 AM	MVNL	Amethi	AYODHYA	EDC-GAURGANI (Amethi)	EDD-JAGDHPUR	EDSD-J JAGDHPUR	33kv Mahona	nadi Pump Kainar	33/11 KV MAHONA	Emergency Rostering	9454998984	05/21/26 4:00:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	Shukil Bazar	33/11 KV RAMSANEHIGHAT	Emergency Rostering	9454998984	05/21/26 4:00:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	Aladpur	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	MAUGORPUR	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	SIRAUJI	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	KHETASARAI	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	RANIMAU	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	MARKMAMU	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	BADOSARAI	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	DARIYABAD (T)	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	BHINKHAPUR	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	BELOKHARA	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	TOWN	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	Itouli	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	LAMUN FLOUR MILL	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	Harichandpur	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	KOTMA DHAM	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	TIKAIT NAGAR (R)	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	KOTMASADAK	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:06:14 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	ZAIIPUR	33/11 KV RAMSANEHIGHAT	Breakdown Shutdown	9453005256	05/21/26 12:00:00 AM	4 H 10 M	33KV Line Fault
5/21/2026 4:04:22 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	DARIYABAD TOWN	33/11 KV DARIYA BAD	Scheduled Rostering	7838981163	05/21/26 11:00:00 AM	2 H 0 M	Rostering
5/21/2026 4:04:22 AM	MVNL	BARA BANKI	AYODHYA	EDC-BARABANKI	EDD-RAMSA NEHI GHAT	EDSD-RAMSA NEHI GHAT	33 kv line fault	HONSEPUR	33/11 KV DARIYA BAD	Scheduled Rostering	7838981162	05/21/26 11:00:00 AM	2 H 0 M	Rostering
5/21/2026 3:48:21 AM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	AKOHI	ASGARGAN	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 3:40:00 AM	1 H 0 M	Rostering
5/21/2026 3:48:21 AM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	AKOHI	SUBSTATION	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 3:40:00 AM	1 H 0 M	Rostering
5/21/2026 3:48:21 AM	MVNL	UNNAO	RAEBARELI	EDC-UNNAO	EDD-3 PURWA	EDSD-MAURAWN	AKOHI	Bhawansingh	33/11KV Maurawan	Scheduled Rostering	9453005039	05/21/26 3:40:00 AM	1 H 0 M	Rostering
5/21/2026 3:48:07 AM	MVNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-RESIDENCY	EDD-RESIDENCY	jawahar nagar Suraj kund Nai basti ki hospital 14 no bairal	Surajkund	33/11 KV RESIDENCY	Planned Shutdown	8004921218	05/21/26 3:43:00 AM	0 H 50 M	Line maintenance
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	LUcknowa	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Gulugur	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Dighaura	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Sahlyia	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Bata	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:44:48 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Gangajaini	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 3:44:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 3:42:21 AM	MVNL	LUCKNOW CENTRAL	CHOWK	EDD-RESIDENCY	EDD-RESIDENCY	EDD-RESIDENCY	jawahar nagar nai basti nabillahal road	CHOWK	33/11 RESIDENCY	Scheduled Rostering	8004921218	05/21/26 3:40:00 AM	2 H 0 M	LT/ABC Line Fault
5/21/2026 3:11:42 AM	MVNL	Lakimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-1 PALIA		RAILWAY STATION DUDDHWA	33/11 KV S/5 DUDDHWA	Scheduled Rostering	9453005091	05/21/26 1:15:00 AM	1 H 0 M	Rostering
5/21/2026 2:11:42 AM	MVNL	Lakimpur KHERI	SITAPUR	EDC-GOLA	EDD-PALIA	EDSD-1 PALIA		DUDDHWA NATIONAL PARK	33/11 KV S/5 DUDDHWA	Scheduled Rostering	9453005091	05/21/26 1:15:00 AM	1 H 0 M	Rostering
5/21/2026 2:08:26 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	LUcknowa	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:08:26 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Harichandpur	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:08:26 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Dighaura	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:08:26 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Sahlyia	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:08:26 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Bata	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:01:25 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Gangajaini	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:01:25 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Bata	33/11 HARCHANDPUR	Emergency Rostering	9453005014	05/21/26 2:07:00 AM	1 H 0 M	Transmission Rostering
5/21/2026 2:01:25 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	RAJA KOTE	Chandapur	Scheduled Rostering	9415905016	05/21/26 2:00:00 AM	0 H 50 M	Rostering
5/21/2026 2:01:25 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Chandapur	Chandapur	Scheduled Rostering	9415905016	05/21/26 2:00:00 AM	0 H 50 M	Rostering
5/21/2026 2:01:25 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD TRIPULA	EDSD-HARCHANDPUR	LUcknowa	Daurta	Chandapur	Scheduled Rostering	9415905016	05/21/26 2:00:00 AM	0 H 50 M	Rostering
5/21/2026 1:59:17 AM	MVNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-RESIDENCY	EDD-RESIDENCY	राजपुरा में आग लगने के कारण फीडर से सम्बंधित क्षेत्र की आपूर्ति बाधित है।	SITAPUR YONIA / BALGARAO	33/11 KV S/5	Breakdown Shutdown	8004921218	05/21/26 1:59:00 AM	1 H 32 M	Transmission Rostering/OT Fuse Burnt/ fire on DT
5/21/2026 1:28:04 AM	MVNL	LUCKNOW	JANPURBAM	MAHANAGAR	EDD-SITAPUR ROAD	EDSD-SITAPUR ROAD	Fazilulaganj	Fazilulaganj	33/11 KV FAZILULAGANJ	Breakdown Shutdown	9415903616	05/21/26 12:30:00 AM	11 H 30 M	LT/ABC Line Fault
5/21/2026 1:26:12 AM	MVNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-DUBAGGA	EDSD-DUBAGGA	ABC लक्षण में आग लग जाने के कारण फीडर से सम्बंधित क्षेत्र की आपूर्ति बाधित है।	BARAWAN KHURD	33/11 KV AMRAPALI DUBAGGA (OLD)	Breakdown Shutdown	8004921275	05/21/26 12:30:00 AM	9 H 30 M	LT/ABC Line Fault
5/21/2026 1:26:12 AM	MVNL	LUCKNOW	AMAUUS	LUCKNOW RURAL	EDD-DUBAGGA	EDSD-DUBAGGA	ABC लक्षण में आग लग जाने के कारण फीडर से सम्बंधित क्षेत्र की आपूर्ति बाधित है।	Dubbagga	33/11 KV AMRAPALI DUBAGGA (OLD)	Breakdown Shutdown	8004921275	05/21/26 12:30:00 AM	9 H 30 M	LT/ABC Line Fault
5/21/2026 1:24:08 AM	MVNL	LUCKNOW	GOMTI NAGAR	GOMTI NAGAR	EDD-GOMTINAGAR	EDSD-GOMTINAGAR	ABC लक्षण में आग लग जाने के कारण फीडर से सम्बंधित क्षेत्र की आपूर्ति बाधित है।	Vihitki khano	Sub-station	Breakdown Shutdown	8004921239	05/21		

BDSD REPORT

ENTRYDATE	DISCOM	DISTRICT	ZONE	CIRCLE	DIVISION	SUBDIVISION	AREA	FEEDER	SUBSTATION	DOWN INFO	SUBSTATION NUMBER	DOWN DATE AND TIME	TIME DURATION	FAULT REASON
5/21/2026 12:33:54 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-1 RAEBARELI	EDSD-1 Madhvan Raebareilly	NIRALANAGAR SATYANAGAR	11KV TOWN 1 FEEDER	Pragati Puram	Planned Shutdown	9453005001	05/21/26 12:32:00 AM	0 H 50 M	Line maintenance
5/21/2026 12:33:54 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-1 RAEBARELI	EDSD-1 Madhvan Raebareilly	SATYANGAR NIRALANAGAR	pragatipuram town	Pragati Puram	Planned Shutdown	9453009001	05/21/26 2:37:00 AM	0 H 50 M	Line maintenance
5/21/2026 12:33:54 AM	MVNL	RAE BARELI	RAEBARELI	EDC-1 RAEBARELI	EDD-1 RAEBARELI	EDSD-1 Madhvan Raebareilly	SATYANGAR NIRALANAGAR	11KV TOWN 1 FEEDER	Pragati Puram	Planned Shutdown	9453005001	05/21/26 2:37:00 AM	0 H 50 M	Line maintenance
5/21/2026 12:24:46 AM	MVNL	LUCKNOW	LUCKNOW CENTRAL	CHOWK	EDD-RESIDENCY	RESIDENCY	Suraj kund jawahar nagar nai basti kk hospital basmandi	Surajkund	33/11 KV RESIDENCY	Planned Shutdown	8004921218	05/21/26 12:23:00 AM	1 H 30 M	Line maintenance
5/21/2026 12:03:44 AM	MVNL	LUCKNOW	GOMTI NAGAR	GOMTI NAGAR	EDD-GOMTINAGAR	VISHVAS KHAND	पोल पर आग लग जाने के कारण पचवटी फीडर से सम्बंधित कपड क्षेत्र की आपूर्ति बाधित	Substation	VISHWAS KHAND	Breakdown Shutdown	8004921238	05/21/26 12:00:00 AM	1 H 0 M	11KV Line Fault